

Continuous water monitoring at Station B (discharge from San Luis Drain), October 2009.

PARAMETER	Flow	Temperature	Boron	Specific Conductance	Selenium (total)	Selenium (total) Load
DATA						
SOURCE	USBR	USBR	CVRWQCB	CVRWQCB	CVRWQCB	Computed
UNITS	cfs	°C	mg/L	µS/cm	µg/L	lbs
Oct-01-2009	12	18.9	6.9	4,250	16.3	1.0
Oct-02-2009	10	18.6	6.6	3,930	14.5	0.8
Oct-03-2009	9	19.0	6.1	3,820	12.1	0.6
Oct-04-2009	8	18.2	6.6	3,600	10.5	0.4
Oct-05-2009	8	17.9	7.2	3,530	11.9	0.5
Oct-06-2009	7	17.5	6.9	3,740	12.1	0.5
Oct-07-2009	8	17.7	7.0	3,860	12.2	0.5
Oct-08-2009	8	18.2	6.6	3,660	11.8	0.5
Oct-09-2009	9	18.6	6.8	3,630	10.5	0.5
Oct-10-2009	13	18.9	6.8	3,550	11.7	0.8
Oct-11-2009	13	19.3	7.0	3,650	12.8	0.9
Oct-12-2009	13	18.9	7.0	3,840	11.9	0.8
Oct-13-2009	18	17.0	6.6	3,660	10.3	1.0
Oct-14-2009	16	17.2	6.6	3,410	9.4	0.8
Oct-15-2009	17	19.2	7.4	3,640	12.0	1.1
Oct-16-2009	15	21.0	5.6	3,870	11.2	0.9
Oct-17-2009	15	21.5	4.3	3,020	9.2	0.7
Oct-18-2009	15	22.1	4.6	2,810	11.9	0.9
Oct-19-2009	15	21.1	5.0	3,270	13.6	1.1
Oct-20-2009	15	19.9	5.7	3,220	16.5	1.4
Oct-21-2009	19	19.1	6.4	3,810	21.6	2.2
Oct-22-2009	22	19.5	6.7	3,890	16.3	1.9
Oct-23-2009	23	19.8	6.8	3,920	16.0	2.0
Oct-24-2009	24	20.0	6.9	3,890	19.4	2.5
Oct-25-2009	25	19.8	6.9	3,970	26.9	3.7
Oct-26-2009	27	19.5	6.9	4,320	31.6	4.5
Oct-27-2009	19	16.7	6.5	4,140	28.2	2.9
Oct-28-2009	20	12.4	6.8	4,200	34.4	3.6
Oct-29-2009	21	11.5	6.6	4,150	31.2	3.6
Oct-30-2009	18	12.3	6.7	4,200	31.4	3.1
Oct-31-2009	17	13.2	6.6	4,270	30.5	2.7
Mean	15	18.2	6.5	3,770	17.1	1.6
Total					Total	
Acre-feet	940				(lbs)	48
Load						
Limitation for October 2009 (lbs)						246