

Continuous water monitoring at Station B (discharge from San Luis Drain), January 2010.

PARAMETER	Flow	Temperature	Boron	Specific Conductance	Selenium (total)	Selenium (total) Load
DATA						
SOURCE	USBR	USBR	CVRWQCB	CVRWQCB	CVRWQCB	Computed
UNITS	cfs	°C	mg/L	µS/cm	µg/L	lbs
Jan-01-2010	19	10.5	8.3	4,880	50.6	5.1
Jan-02-2010	20	10.5	8.8	5,020	53.7	5.8
Jan-03-2010	19	10.8	8.6	5,130	55.1	5.7
Jan-04-2010	20	10.9	8.0	4,840	37.6	4.1
Jan-05-2010	21	10.7	7.3	4,650	37.0	4.1
Jan-06-2010	21	10.5	7.4	4,710	51.0	5.8
Jan-07-2010	21	10.0	7.2	4,610	49.9	5.7
Jan-08-2010	20	9.9	7.5	4,680	50.2	5.5
Jan-09-2010	21	9.9	7.4	4,820	52.2	5.8
Jan-10-2010	21	9.8	7.5	4,750	51.3	5.9
Jan-11-2010	21	9.6	7.5	4,730	51.1	5.8
Jan-12-2010	21	10.0	7.5	4,780	56.0	6.2
Jan-13-2010	23	11.2	7.4	4,700	51.3	6.3
Jan-14-2010	24	11.7	7.4	4,760	54.4	7.0
Jan-15-2010	24	11.6	7.2	4,590	47.9	6.2
Jan-16-2010	23	11.8	7.4	4,620	47.4	6.0
Jan-17-2010	24	11.6	7.9	4,760	53.8	7.0
Jan-18-2010	27	11.3	7.2	4,790	51.9	7.5
Jan-19-2010	32	10.5	6.8	4,490	49.9	8.6
Jan-20-2010	35	10.2	7.0	4,470	53.8	10.0
Jan-21-2010	31	9.8	7.0	4,500	56.3	9.5
Jan-22-2010	33	9.5	7.2	4,550	55.8	9.9
Jan-23-2010	28	9.6	8.2	4,790	56.3	8.6
Jan-24-2010	26	9.6	7.9	4,900	54.9	7.7
Jan-25-2010	22	10.0	8.1	4,820	53.2	6.2
Jan-26-2010	20	10.2	8.7	4,870	55.0	5.8
Jan-27-2010	20	10.8	8.4	5,000	42.7	4.5
Jan-28-2010	23	11.3	8.7	4,740	46.6	5.7
Jan-29-2010	22	12.2	8.1	4,720	41.0	4.8
Jan-30-2010	19	12.8	7.7	4,460	25.6	2.7
Jan-31-2010	22	12.7	7.3	4,150	22.9	2.7
Mean	23	10.7	7.7	4,720	48.9	6.2
Total					Total	
Acre-feet	1,430				(lbs)	192
Load						
Limitation for January 2010 (lbs)						398