

Continuous water monitoring at Station B (discharge from San Luis Drain), June 2010.

PARAMETER	Flow	Temperature	Boron	Specific Conductance	Selenium (total)	Selenium (total) Load
DATA SOURCE	USBR	USBR	CVRWQCB	CVRWQCB	CVRWQCB	Computed
UNITS	cfs	°C	mg/L	µS/cm	µg/L	lbs
Jun-01-2010	26	24.4	8.3	4,580	52.9	7.5
Jun-02-2010	22	24.8	7.8	4,370	49.4	5.8
Jun-03-2010	19	25.5	8.0	4,310	47.3	4.8
Jun-04-2010	18	26.1	8.7	4,560	49.8	4.9
Jun-05-2010	19	26.9	8.0	4,430	49.0	5.1
Jun-06-2010	20	27.5	8.9	4,500	51.8	5.6
Jun-07-2010	19	27.3	8.8	4,650	51.6	5.4
Jun-08-2010	18	28.3	9.2	4,770	50.8	5.0
Jun-09-2010	14	27.4	9.5	4,730	49.4	3.7
Jun-10-2010	13	25.0	8.8	4,780	45.7	3.2
Jun-11-2010	12	21.8	8.7	4,640	49.1	3.2
Jun-12-2010	14	21.1	9.9	4,790	64.3	4.8
Jun-13-2010	13	23.1	10.0	5,280	62.9	4.5
Jun-14-2010	19	25.2	10.0	5,500	59.8	6.3
Jun-15-2010	19	26.1	10.0	5,620	50.0	5.1
Jun-16-2010	21	24.7	10.0	5,190	46.2	5.3
Jun-17-2010	26	23.3	9.4	5,020	42.2	5.8
Jun-18-2010	23	25.0	8.3	4,330	33.2	4.2
Jun-19-2010	21	25.4	7.4	3,980	32.6	3.7
Jun-20-2010	25	24.1	7.2	3,930	30.3	4.2
Jun-21-2010	24	23.7	6.9	3,750	32.3	4.2
Jun-22-2010	26	24.0	6.3	3,840	26.0	3.6
Jun-23-2010	28	26.1	6.6	3,550	27.5	4.1
Jun-24-2010	17	26.3	7.2	3,480	31.0	2.8
Jun-25-2010	14	26.8	7.0	3,720	28.5	2.2
Jun-26-2010	20	27.5	6.9	3,490	25.8	2.8
Jun-27-2010	30	28.5	8.3	4,070	42.7	6.8
Jun-28-2010	29	29.2	7.8	4,080	28.1	4.4
Jun-29-2010	22	29.3	7.7	4,060	28.8	3.5
Jun-30-2010	16	28.5	9.0	4,560	45.8	3.9
.
Mean	20	25.8	8.4	4,420	42.8	4.6
Total					Total	
Acre-feet	1,210				(lbs)	137
Load						
Limitation for June 2010 (lbs)						212