

Continuous water monitoring at Station B (discharge from San Luis Drain), October 2010.

PARAMETER	Flow	Temperature	Boron	Specific Conductance	Selenium (total)	Selenium (total) Load
DATA						
SOURCE	USBR	USBR	CVRWQCB	CVRWQCB	CVRWQCB	Computed
UNITS	cfs	°C	mg/L	µS/cm	µg/L	lbs
Oct-01-2010	7	25.4	8.5	4,410	11.9	0.4
Oct-02-2010	7	25.1	8.6	4,460	10.7	0.4
Oct-03-2010	7	25.5	8.7	4,550	8.9	0.3
Oct-04-2010	7	23.6	8.2	4,570	8.1	0.3
Oct-05-2010	6	21.8	8.2	4,390	9.6	0.3
Oct-06-2010	7	20.5	8.1	4,330	9.1	0.3
Oct-07-2010	8	20.3	7.2	4,200	8.0	0.3
Oct-08-2010	12	19.7	7.4	3,840	8.0	0.5
Oct-09-2010	11	20.4	7.4	3,980	8.6	0.5
Oct-10-2010	12	20.8	7.2	3,920	8.5	0.5
Oct-11-2010	10	22.0	7.1	3,890	8.0	0.4
Oct-12-2010	11	22.1	5.9	3,770	6.5	0.4
Oct-13-2010	12	21.9	5.6	3,290	6.4	0.4
Oct-14-2010	12	21.9	5.1	3,230	8.0	0.5
Oct-15-2010	11	22.5	5.1	2,970	9.4	0.6
Oct-16-2010	13	22.5	4.8	3,000	9.0	0.6
Oct-17-2010	13	21.0	4.9	2,900	11.6	0.8
Oct-18-2010	15	19.6	4.9	3,030	10.0	0.8
Oct-19-2010	17	19.4	4.7	2,920	7.3	0.7
Oct-20-2010	16	19.7	5.4	3,190	6.7	0.6
Oct-21-2010	14	19.7	6.1	3,180	7.5	0.6
Oct-22-2010	13	19.2	5.8	3,760	11.1	0.8
Oct-23-2010	13	18.9	7.1	3,500	10.5	0.8
Oct-24-2010	13	18.2	8.3	4,420	12.4	0.9
Oct-25-2010	11	17.6	7.8	4,530	14.5	0.9
Oct-26-2010	10	16.5	7.4	4,350	15.2	0.8
Oct-27-2010	11	15.4	7.0	4,180	11.1	0.7
Oct-28-2010	11	15.7	6.2	3,840	9.6	0.5
Oct-29-2010	10	15.6	6.4	3,600	8.5	0.5
Oct-30-2010	12	15.9	6.7	3,690	9.3	0.6
Oct-31-2010	12	15.7	7.7	3,760	10.5	0.7
<b>Mean</b>	11	20.1	6.8	3,800	9.5	0.6
<b>Total</b>					<b>Total</b>	
<b>Acre-feet</b>	930				<b>(lbs)</b>	17
<b>Load</b>						
<b>Limitation for October 2010 (lbs)</b>						260