

Continuous water monitoring at Station B (discharge from San Luis Drain), February 2011.

PARAMETER	Flow	Temperature	Boron	Specific Conductance	Selenium (total)	Selenium (total) Load
DATA						
SOURCE	USBR	USBR	CVRWQCB	CVRWQCB	CVRWQCB	Computed
UNITS	cfs	°C	mg/L	µS/cm	µg/L	lbs
Feb-01-2011	19	10.7	9.1	5,050	27.0	2.8
Feb-02-2011	18	10.7	8.5	5,050	20.5	2.0
Feb-03-2011	23	10.7	8.8	4,920	18.3	2.2
Feb-04-2011	25	11.1	9.0	5,000	20.4	2.8
Feb-05-2011	28	11.6	9.8	5,420	23.8	3.6
Feb-06-2011	30	12.3	9.5	5,160	33.2	5.4
Feb-07-2011	34	12.9	9.8	5,380	40.7	7.4
Feb-08-2011	31	11.3	10.0	5,620	56.9	9.5
Feb-09-2011	34	10.5	10.0	5,870	59.3	11.0
Feb-10-2011	31	11.0	9.9	5,670	59.3	10.0
Feb-11-2011	29	11.3	9.2	5,360	58.5	9.1
Feb-12-2011	28	11.8	9.5	5,350	56.1	8.4
Feb-13-2011	26	12.6	9.8	5,550	57.1	7.9
Feb-14-2011	30	12.8	9.0	5,320	45.2	7.3
Feb-15-2011	33	13.1	8.9	5,140	43.0	7.8
Feb-16-2011	32	13.0	NA***	5,090	P	P
Feb-17-2011	34	11.6	NA***	5,370	P	P
Feb-18-2011	35	10.5	NA***	5,110	P	P
Feb-19-2011	55	10.4	NA***	5,070	P	P
Feb-20-2011	84	10.6	NA***	4,760	P	P
Feb-21-2011	77	11.4	NA***	5,180	P	P
Feb-22-2011	62	11.8	NA***	4,950	P	P
Feb-23-2011	54	12.3	NA***	5,010	P	P
Feb-24-2011	50	12.2	NA***	5,080	P	P
Feb-25-2011	51	11.5	NA***	4,880	P	P
Feb-26-2011	49	10.7	NA***	4,960	P	P
Feb-27-2011	52	10.3	NA***	5,010	P	P
Feb-28-2011	51	10.8	NA***	4,930	P	P
.
.
.
Mean	39	11.5	9.4	5,190	41.3	6.5
Total					Total	
Acre-feet	2,190				(lbs)	256 e
Load						
Limitation for February 2011 (lbs)						488