

Continuous water monitoring at Station B (discharge from San Luis Drain), May 2012.

PARAMETER	Flow	Temperature	Boron	Specific Conductance	Selenium (total)	Selenium (total) Load
DATA						
SOURCE	USBR	USBR	CVRWQCB	CVRWQCB	CVRWQCB	Computed
UNITS	cfs	°C	mg/L	µS/cm	µg/L	lbs
May-01-2012	12	19.1	11.0	4,660	21.0	1.4
May-02-2012	12	17.7	11.0	4,700	29.0	1.9
May-03-2012	11	18.1	11.0	4,870	29.0	1.7
May-04-2012	8	18.2	11.0	4,760	28.0	1.3
May-05-2012	6	17.9	11.0	4,710	30.0	1.0
May-06-2012	6	21.5	10.0	4,720	33.0	1.0
May-07-2012	7	21.9	10.0	4,800	37.0	1.4
May-08-2012	8	23.8	11.0	4,880	39.0	1.6
May-09-2012	7	25.6	11.0	4,970	39.0	1.5
May-10-2012	6	21.3	11.0	4,960	36.0	1.2
May-11-2012	9	23.1	12.0	4,880	37.0	1.8
May-12-2012	11	24.8	12.0	4,870	36.0	2.1
May-13-2012	9	21.9	10.0	4,770	31.0	1.6
May-14-2012	8	19.8	11.0	4,540	33.0	1.4
May-15-2012	8	21.4	12.0	4,840	36.0	1.6
May-16-2012	13	23.4	9.9	4,900	34.0	2.4
May-17-2012	14	21.9	12.0	4,760	31.0	2.4
May-18-2012	10	20.4	12.0	4,770	37.0	2.0
May-19-2012	11	22.8	13.0	4,650	40.0	2.4
May-20-2012	11	24.3	14.0	4,920	41.0	2.5
May-21-2012	13	23.2	13.0	5,040	44.0	3.0
May-22-2012	17	22.9	14.0	5,170	44.0	4.0
May-23-2012	14	21.2	13.0	5,180	45.0	3.3
May-24-2012	11	20.8	11.0	4,770	44.0	2.7
May-25-2012	10	14.9	11.0	4,650	44.0	2.3
May-26-2012	12	16.7	11.0	4,470	46.0	2.9
May-27-2012	12	19.0	11.0	4,590	43.0	2.7
May-28-2012	11	20.7	10.0	4,440	39.0	2.3
May-29-2012	14	20.5	10.0	4,360	46.0	3.4
May-30-2012	15	23.6	9.7	4,640	49.0	3.9
May-31-2012	14	26.9	10.0	4,700	51.0	4.0
Mean	11	21.3	11.3	4,470	37.8	2.2
Total					Total	
Acre-feet	660				(lbs)	69
Load						
Limitation for May 2012 (lbs)						197