

Continuous water monitoring at Station B (discharge from San Luis Drain), August 2012.

PARAMETER	Flow	Temperature	Boron	Specific Conductance	Selenium (total)	Selenium (total) Load
DATA						
SOURCE	USBR	USBR	CVRWQCB	CVRWQCB	CVRWQCB	Computed
UNITS	cfs	°C	mg/L	µS/cm	µg/L	lbs
Aug-01-2012	10	27.1	9.9	5,050	32.0	1.8
Aug-02-2012	9	27.4	9.0	5,060	29.0	1.4
Aug-03-2012	7	26.9	7.3	4,820	28.0	1.1
Aug-04-2012	6	24.7	9.1	4,610	24.0	0.8
Aug-05-2012	6	24.7	9.1	4,370	21.0	0.7
Aug-06-2012	9	25.4	9.6	4,180	20.0	0.9
Aug-07-2012	10	26.2	11.0	4,500	21.0	1.1
Aug-08-2012	9	26.4	14.0	5,010	21.0	1.0
Aug-09-2012	12	28.9	14.0	5,410	21.0	1.4
Aug-10-2012	17	29.6	13.0	5,290	22.0	2.0
Aug-11-2012	12	29.8	12.0	5,310	31.0	2.1
Aug-12-2012	10	30.7	9.1	5,310	39.0	2.2
Aug-13-2012	8	31.0	10.0	5,310	27.0	1.2
Aug-14-2012	8	31.4	9.7	5,380	27.0	1.2
Aug-15-2012	8	29.1	9.5	5,120	28.0	1.2
Aug-16-2012	8	27.4	8.6	5,130	29.0	1.3
Aug-17-2012	9	27.5	9.3	5,020	31.0	1.6
Aug-18-2012	9	27.1	8.9	4,760	28.0	1.4
Aug-19-2012	10	27.1	8.6	4,530	29.0	1.6
Aug-20-2012	9	25.6	8.4	4,480	31.0	1.5
Aug-21-2012	10	26.2	9.4	4,600	29.0	1.6
Aug-22-2012	12	25.4	10.0	5,020	24.0	1.6
Aug-23-2012	10	26.0	11.0	5,300	21.0	1.1
Aug-24-2012	8	25.4	10.0	5,590	22.0	1.0
Aug-25-2012	9	24.8	8.4	5,110	26.0	1.2
Aug-26-2012	7	22.1	8.7	4,640	30.0	1.2
Aug-27-2012	7	22.0	8.7	4,640	33.0	1.2
Aug-28-2012	6	25.1	8.5	4,760	36.0	1.1
Aug-29-2012	6	24.5	8.3	4,840	37.0	1.1
Aug-30-2012	6	26.5	8.7	4,940	35.0	1.1
Aug-31-2012	6	21.5	8.7	5,020	30.0	0.9
Mean	9	26.6	9.7	4,940	27.8	1.3
Total					Total	
Acre-feet	540				(lbs)	40
Load						
Limitation for August 2012 (lbs)						137