

Continuous water monitoring at Station B (discharge from San Luis Drain), September 2012.

PARAMETER	Flow	Temperature	Boron	Specific Conductance	Selenium (total)	Selenium (total) Load
DATA						
SOURCE	USBR	USBR	CVRWQCB	CVRWQCB	CVRWQCB	Computed
UNITS	cfs	°C	mg/L	µS/cm	µg/L	lbs
Sep-01-2012	5	19.8	8.0	4,950	25.0	0.7
Sep-02-2012	6	23.5	7.7	4,710	24.0	0.8
Sep-03-2012	9	26.2	7.8	4,410	26.0	1.2
Sep-04-2012	8	25.5	7.9	4,530	27.0	1.2
Sep-05-2012	7	25.0	8.2	4,570	23.0	0.8
Sep-06-2012	6	25.0	8.2	4,540	21.0	0.6
Sep-07-2012	6	24.5	9.0	4,540	21.0	0.6
Sep-08-2012	5	25.6	9.2	4,590	20.0	0.6
Sep-09-2012	6	24.5	9.2	4,690	20.0	0.7
Sep-10-2012	9	22.7	9.0	4,870	17.0	0.8
Sep-11-2012	8	24.0	9.2	4,820	15.0	0.6
Sep-12-2012	6	24.4	9.5	4,830	14.0	0.5
Sep-13-2012	6	26.6	9.5	4,920	17.0	0.5
Sep-14-2012	5	26.6	9.8	5,000	19.0	0.6
Sep-15-2012	6	25.6	10.0	5,090	19.0	0.6
Sep-16-2012	6	25.1	10.0	5,150	18.0	0.6
Sep-17-2012	8	22.9	10.0	5,170	17.0	0.8
Sep-18-2012	9	21.6	10.0	5,090	16.0	0.8
Sep-19-2012	7	21.5	9.2	4,950	16.0	0.6
Sep-20-2012	6	21.5	9.1	4,970	17.0	0.6
Sep-21-2012	6	23.1	10.0	5,030	16.0	0.5
Sep-22-2012	6	24.9	12.0	5,090	14.0	0.4
Sep-23-2012	6	25.3	10.0	4,980	13.0	0.4
Sep-24-2012	7	21.9	8.4	4,650	12.0	0.4
Sep-25-2012	6	22.8	6.8	4,430	8.8	0.3
Sep-26-2012	6	23.3	6.2	4,080	5.8	0.2
Sep-27-2012	6	24.0	7.2	3,550	6.7	0.2
Sep-28-2012	8	24.4	8.6	3,830	7.8	0.3
Sep-29-2012	11	24.0	8.8	4,300	8.1	0.5
Sep-30-2012	10	25.0	7.6	4,060	6.5	0.4
.
Mean	7	24.6	8.9	4,680	16.4	0.6
Total					Total	
Acre-feet	410				(lbs)	18
Load						
Limitation for September 2012 (lbs)						235