

Continuous water monitoring at Station B (discharge from San Luis Drain), November 2013.

PARAMETER	Flow	Temperature	Boron	Specific Conductance	Selenium (total)	Selenium (total) Load
DATA						
SOURCE	USBR	USBR	CVRWQCB	CVRWQCB	CVRWQCB	Computed
UNITS	cfs	°C	mg/L	µS/cm	µg/L	lbs
Nov-01-2013	11	14.9	14.0	5,530	7.3	0.4
Nov-02-2013	13	15.3	13.0	5,520	6.3	0.4
Nov-03-2013	12	14.5	11.0	5,210	6.1	0.4
Nov-04-2013	13	14.8	12.0	5,010	5.1	0.4
Nov-05-2013	15	13.8	12.0	5,480	5.7	0.4
Nov-06-2013	13	13.5	10.0	5,720	4.3 U	0.3
Nov-07-2013	11	14.5	12.0	5,050	3.9	0.2
Nov-08-2013	11	15.1	14.0	5,590	5.3	0.3
Nov-09-2013	11	14.5	13.0	5,700	6.8	0.4
Nov-10-2013	11	14.3	13.0	5,490	6.8	0.4
Nov-11-2013	12	14.2	11.0	5,330	6.6	0.4
Nov-12-2013	12	15.9	10.0	4,900	7.0	0.4
Nov-13-2013	12	15.0	11.0	4,630	6.8	0.4
Nov-14-2013	12	15.6	10.0	4,680	5.6	0.4
Nov-15-2013	12	12.4	9.7	4,450	4.9	0.3
Nov-16-2013	13	12.0	10.0	4,640	5.2	0.4
Nov-17-2013	12	12.1	10.0	4,640	5.6	0.4
Nov-18-2013	12	12.0	11.0	5,000	5.8	0.4
Nov-19-2013	12	14.2	11.0	5,040	5.8	0.4
Nov-20-2013	12	14.9	11.0	4,970	6.0	0.4
Nov-21-2013	11	11.4	9.8	4,800	6.2	0.4
Nov-22-2013	15	8.6	11.0	4,720	6.7	0.6
Nov-23-2013	16	8.5	11.0	5,050	6.5	0.6
Nov-24-2013	14	9.5	10.0	4,860	6.1	0.4
Nov-25-2013	13	10.4	10.0	4,860	6.3	0.4
Nov-26-2013	13	9.7	10.0	5,080	5.8	0.4
Nov-27-2013	12	12.0	10.0	4,860	6.6	0.4
Nov-28-2013	13	11.9	12.0	5,020	7.2	0.5
Nov-29-2013	13	11.8	11.0	5,550	10.0	0.7
Nov-30-2013	12	10.8	9.6	5,050	8.4	0.5
.	.	.	.	.	.	.
<b>Mean</b>	12	12.9	11.1	5,080	6.3	0.4
<b>Total</b>					<b>Total</b>	
<b>Acre-feet</b>	737				<b>(lbs)</b>	13
<b>Load</b>						
<b>Limitation for November 2013 (lbs)</b>						55