

Continuous water monitoring at Station B (discharge from San Luis Drain), December 2013.

PARAMETER	Flow	Temperature	Boron	Specific Conductance	Selenium (total)	Selenium (total) Load
DATA						
SOURCE	USBR	USBR	CVRWQCB	CVRWQCB	CVRWQCB	Computed
UNITS	cfs	°C	mg/L	µS/cm	µg/L	lbs
Dec-01-2013	12	11.2	10.0	4,720	8.0	0.5
Dec-02-2013	12	10.9	9.3	4,730	7.7	0.5
Dec-03-2013	12	9.6	9.4	4,730	6.8	0.4
Dec-04-2013	13	4.8	10.0	4,890	7.0	0.5
Dec-05-2013	13	2.3	12.0	5,330	8.1	0.6
Dec-06-2013	13	3.6	11.0	5,600	9.7	0.7
Dec-07-2013	13	6.2	11.0	5,230	8.6	0.6
Dec-08-2013	14	1.6	11.0	5,220	8.3	0.6
Dec-09-2013	19	2.3	NA	5,600	8.6	0.9
Dec-10-2013	14	3.0	NA	6,290	11.0	0.8
Dec-11-2013	12	4.9	14.0	6,250	13.0	0.8
Dec-12-2013	11	4.8	13.0	6,120	12.0	0.7
Dec-13-2013	11	5.7	13.0	5,960	12.0	0.7
Dec-14-2013	11	5.8	13.0	5,990	11.0	0.7
Dec-15-2013	11	6.6	14 T	6,160	18.0	1.1
Dec-16-2013	11	7.7	11.0	6,430	16.0	1.0
Dec-17-2013	11	7.7	9.5	6,350	13.0	0.8
Dec-18-2013	11	11.2	9.8	5,920	11.0	0.7
Dec-19-2013	11	10.1	9.2	4,810	9.8	0.6
Dec-20-2013	12	8.5	9.4	4,690	9.4	0.6
Dec-21-2013	12	6.8	11.0	4,930	10.0	0.7
Dec-22-2013	12	7.7	11.0	5,340	10.0	0.6
Dec-23-2013	14	8.2	11.0	5,480	9.9	0.7
Dec-24-2013	13	9.1	11.0	5,350	10.0	0.7
Dec-25-2013	12	8.0	12.0	5,420	11.0	0.7
Dec-26-2013	11	8.6	12.0	5,560	12.0	0.7
Dec-27-2013	11	7.1	12.0	5,720	13.0	0.8
Dec-28-2013	11	7.9	12.0	5,850	12.0	0.7
Dec-29-2013	11	7.2	11.0	5,530	17.0	1.0
Dec-30-2013	11	7.4	11.0	5,390	17.0	1.0
Dec-31-2013	11	7.7	10.0	5,180	19.0	1.1
<b>Mean</b>	12	6.9	11.0	5,510	11.1	0.8
<b>Total</b>					<b>Total</b>	
<b>Acre-feet</b>	748				<b>(lbs)</b>	23
<b>Load</b>						
<b>Limitation for December 2013 (lbs)</b>						152