

Continuous water monitoring at Station B (discharge from San Luis Drain), January 2014.

PARAMETER	Flow	Temperature	Specific Conductance	Total Suspended Solids	Boron	Selenium (total)	Selenium (total) Load
<b>DATA</b>							
<b>SOURCE</b>	<b>SLDMWA+</b>	<b>SLDMWA</b>	<b>SLDMWA</b>	<b>SLDMWA/USBR</b>	<b>USBR</b>	<b>USBR</b>	<b>Calculated</b>
<b>UNITS</b>	<b>cfs</b>	<b>°C</b>	<b>µS/cm</b>	<b>mg/L</b>	<b>mg/L</b>	<b>µg/L</b>	<b>lbs</b>
Jan-01-2014	10	8.1	5,170		9.3	15.0	0.8
Jan-02-2014	10	8.7	4,960		9.8	16.0	0.9
Jan-03-2014	10	8.4	4,840		8.9	13.0	0.7
Jan-04-2014	10	8.6	4,620		9.0	12.0	0.6
Jan-05-2014	10	8.0	4,460		8.6	10.0	0.5
Jan-06-2014	10	7.8	4,550		9.0	10.0	0.5
Jan-07-2014	11	9.8	4,710		10.0	11.0	0.6
Jan-08-2014	11	8.6	5,120		9.8	11.0	0.7
Jan-09-2014	13	10.4	4,810		9.3	11.0	0.8
Jan-10-2014	13	10.7	4,740		9.4	9.2	0.6
Jan-11-2014	13	8.0	4,740		8.5	9.9	0.7
Jan-12-2014	11	8.3	4,840		8.9	11.0	0.6
Jan-13-2014	14	7.4	5,000	13	8.8	11.0	0.8
Jan-14-2014	15	9.3	5,060		8.9	11.0	0.9
Jan-15-2014	17	9.4	5,370		11.0	17.0	1.5
Jan-16-2014	17	10.1	5,630		9.8	14.0	1.3
Jan-17-2014	15	9.7	5,300		8.6	13.0	1.0
Jan-18-2014	16	9.7	5,060		9.9	14.0	1.2
Jan-19-2014	18	9.6	5,370		10.0	14.0	1.4
Jan-20-2014	17	9.6	5,390		9.9	14.0	1.3
Jan-21-2014	17	8.3	5,470		9.8	14.0	1.2
Jan-22-2014	17	9.7	5,260		9.2	15.0	1.4
Jan-23-2014	18	9.8	5,160		11.0	14.0	1.3
Jan-24-2014	18	12.6	5,870		12.0	15.0	1.5
Jan-25-2014	19	13.3	6,290		14.0	16.0	1.6
Jan-26-2014	22	10.5	6,780		14.0	16.0	1.9
Jan-27-2014	25	10.9	6,500		13.0	17.0	2.3
Jan-28-2014	28	14.8	6,110		12.0	19.0	2.8
Jan-29-2014	24	16.9	5,920		12.0	18.0	2.4
Jan-30-2014	24	14.0	5,460		10.0	20.0	2.5
Jan-31-2014	20	11.6	5,590		12.0	22.0	2.4
<b>Mean</b>	<b>16</b>	<b>10.1</b>	<b>5290.0</b>	<b>13</b>	<b>10.2</b>	<b>14.0</b>	<b>1.2</b>
						<b>Total (lbs)</b>	<b>39</b>
<b>Load</b>							
<b>Limitation for January 2014 (lbs)</b>							<b>151</b>