

Continuous water monitoring at Station B (discharge from San Luis Drain), February 2014.

PARAMETER	Flow	Temperature	Specific Conductance	Total Suspended Solids	Boron	Selenium (total)	Selenium (total) Load
DATA							
SOURCE	SLDMWA+	SLDMWA	SLDMWA	SLDMWA/USBR	USBR	USBR	Calculated
UNITS	cfs	°C	µS/cm	mg/L	mg/L	µg/L	lbs
Feb-01-2014	22	8.2	5,940		12.0	20.0	2.3
Feb-02-2014	17	5.7	5,780		12.0	24.0	2.2
Feb-03-2014	13	8.4	5,960		12.0	22.0	1.6
Feb-04-2014	22	8.0	6,060		12.0	23.0	2.8
Feb-05-2014	27	9.8	5,840		12.0	22.0	3.1
Feb-06-2014	22	9.2	6,350		13.0	21.0	2.5
Feb-07-2014	23	10.1	6,040		13.0	20.0	2.5
Feb-08-2014	39	12.8	5,640		11.0	20.0	4.2
Feb-09-2014	42	15.2	5,950		13.0	22.0	4.9
Feb-10-2014	40	14.7	6,200	139	13.0	25.0	5.4
Feb-11-2014	28	13.3	6,220		13.0	32.0	4.9
Feb-12-2014	25	13.8	6,050		12.0	31.0	4.1
Feb-13-2014	22	16.3	6,180		13.0	30.0	3.5
Feb-14-2014	23	14.9	6,310		13.0	28.0	3.4
Feb-15-2014	24	13.2	6,550		14.0	25.0	3.2
Feb-16-2014	23	15.1	6,520		14.0	24.0	3.0
Feb-17-2014	24	11.6	6,680		15.0	26.0	3.4
Feb-18-2014	24	11.4	6,590		14.0	27.0	3.5
Feb-19-2014	32	13.3	6,420		14.0	30.0	5.1
Feb-20-2014	28	12.3	6,610		14.0	32.0	4.9
Feb-21-2014	18	12.8	6,390		13.0	33.0	3.1
Feb-22-2014	13	13.9	6,360		12.0	30.0	2.0
Feb-23-2014	10	14.8	6,090		12.0	29.0	1.6
Feb-24-2014	9	15.8	5,860		12.0	29.0	1.4
Feb-25-2014	9	15.9	5,770		12.0	28.0	1.3
Feb-26-2014	11	13.7	5,660		11.0	27.0	1.6
Feb-27-2014	14	15.1	5,300		9.9	24.0	1.7
Feb-28-2014	39	13.6	5,340		12.0	23.0	4.8
Mean	23	12.6	6,100	139	12.6	26.0	3.1
						Total (lbs)	88
Load Limitation for February 2014 (lbs)							93