

Continuous water monitoring at Station B (discharge from San Luis Drain), April 2014.

PARAMETER	Flow	Temperature	Specific Conductance	Total Suspended Solids	Boron	Selenium (total)	Selenium (total) Load
DATA							
SOURCE	SLDMWA ♦	SLDMWA	SLDMWA	SLDMWA/USBR	USBR	USBR	Calculated
UNITS	cfs	°C	µS/cm	mg/L	mg/L	µg/L	lbs
Apr-01-2014	12	9.2	5,490		12.0	9.6	0.6
Apr-02-2014	10	12.1	5,540		12.0	10.0	0.6
Apr-03-2014	9	13.5	5,740		13.0	11.4	0.6
Apr-04-2014	10	13.1	6,150		13.0	13.2	0.7
Apr-05-2014	10	13.8	6,430		12.0	14.8	0.8
Apr-06-2014	10	16.6	6,310		12.0	18.1	1.0
Apr-07-2014	9	20.4	6,220	21	12.0	20.8	1.1
Apr-08-2014	9	22.7	6,540		12.0	20.3	1.0
Apr-09-2014	8	22.5	6,690		11.0	18.4	0.8
Apr-10-2014	7	20.6	6,560		11.0	17.5	0.7
Apr-11-2014	7	20.4	6,450		12.0	18.8	0.7
Apr-12-2014	6	18.8	6,400		11.0	19.2	0.6
Apr-13-2014	6	17.5	6,400		11.0	17.6	0.5
Apr-14-2014	6	20.3	6,430	36	12.0	17.0	0.5
Apr-15-2014	6	21.5	6,660		12.0	16.7	0.5
Apr-16-2014	5	20.1	6,780		13.0	15.8	0.5
Apr-17-2014	6	21.9	6,810		13.0	14.4	0.4
Apr-18-2014	7	20.1	6,750		13.0	13.2	0.5
Apr-19-2014	7	19.3	6,630		12.0	9.8	0.4
Apr-20-2014	6	18.9	6,530		12.0	4.7	0.1
Apr-21-2014	6	21.1	6,480	62	12.0	9.5	0.3
Apr-22-2014	5	17.4	6,570		13.0	9.5	0.3
Apr-23-2014	3	15.6	6,530		12.0	9.9	0.2
Apr-24-2014	5	18.3	6,540		13.0	7.3	0.2
Apr-25-2014	6	14.5	6,530		14.0	8.7	0.3
Apr-26-2014	9	15.7	6,550		16.0	4.3	0.2
Apr-27-2014	14	16.9	6,910		17.0	6.3	0.5
Apr-28-2014	13	16.6	7,410	170	19.0	6.9	0.5
Apr-29-2014	13	20.5	8,070		17.0	25.7	1.8
Apr-30-2014	17	24.1	7,950		17.0	24.0	2.3
Mar-31-2014	11	13.4	5,440	27	11.0	8.4	0.5
Mean	8	18.1	6,568	72	13.0	13.8	0.6
						Total (lbs)	19
Load							
Limitation for April 2014 (lbs)							101