

Continuous water monitoring at Station B (discharge from San Luis Drain), May 2014.

PARAMETER	Flow	Temperature	Specific Conductance	Total Suspended Solids	Boron	Selenium (total)	Selenium (total) Load
DATA							
SOURCE	SLDMWA ♦	SLDMWA	SLDMWA	SLDMWA/USBR	USBR	USBR	Calculated
UNITS	cfs	°C	µS/cm	mg/L	mg/L	µg/L	lbs
May-01-2014	14	26.2	7,990		NA	25.1	1.9
May-02-2014	10	24.0	7,010		NA	23.0	1.3
May-03-2014	9	20.4	6,050		NA	25.3	1.3
May-04-2014	10	19.2	6,240		NA	29.0	1.5
May-05-2014	9	17.6	6,200	33	NA	29.0	1.5
May-06-2014	9	16.6	5,970		NA	26.2	1.3
May-07-2014	8	17.7	5,950		10.0	21.9	1.0
May-08-2014	6	20.0	5,910		11.0	18.9	0.6
May-09-2014	6	20.8	5,950		11.0	18.1	0.6
May-10-2014	5	17.0	6,050		11.0	18.6	0.5
May-11-2014	5	20.1	6,180		12.0	17.1	0.4
May-12-2014	6	21.0	6,290	49	12.0	10.4	0.3
May-13-2014	7	24.8	6,440		12.0	10.6	0.4
May-14-2014	6	26.9	6,370		12.0	7.7	0.2
May-15-2014	5	27.4	6,470		12.0	14.4	0.4
May-16-2014	5	25.2	6,620		12.0	12.2	0.3
May-17-2014	4	23.2	6,710		12.0	10.9	0.3
May-18-2014	4	21.1	6,700		12.0	10.6	0.3
May-19-2014	5	19.1	6,730	45	12.0	10.9	0.3
May-20-2014	5	18.6	6,790		12.0	11.1	0.3
May-21-2014	6	21.7	6,760		12.0	11.0	0.3
May-22-2014	6	22.9	6,730		13.0	5.1	0.2
May-23-2014	6	24.9	7,090		13.0	5.9	0.2
May-24-2014	6	25.8	7,350		14.0	5.3	0.2
May-25-2014	6	26.4	6,980		15.0	2.0	0.1
May-26-2014	6	25.8	7,220		15.0	5.6	0.2
May-27-2014	7	24.6	7,470	58	14.0	2.5	0.1
May-28-2014	7	20.4	7,700		14.0	8.0	0.3
May-29-2014	6	22.3	7,700		15.0	4.6	0.1
May-30-2014	6	23.4	7,600		15.0	7.5	0.2
May-31-2014	6	20.9	7,850		17.0	13.6	0.4
Mean	7	22.1	6,740	46	12.8	13.6	0.5
						Total (lbs)	17
Load							
Limitation for May 2014 (lbs)							105