

Continuous water monitoring at Station B (discharge from San Luis Drain), August 2014.

PARAMETER	Flow	Temperature	Specific Conductance	Total Suspended Solids	Boron	Selenium (total)	Selenium (total) Load
DATA							
SOURCE	SLDMWA ♦	SLDMWA	SLDMWA	SLDMWA/USBR	USBR	USBR	Calculated
UNITS	cfs	°C	µS/cm	mg/L	mg/L	µg/L	lbs
Aug-01-2014	4	30.0	10,100	NA	20.0	11.5	0.2
Aug-02-2014	3	29.1	10,200	NA	21.0	11.2	0.2
Aug-03-2014	3	25.8	10,500	NA	22.0	11.4	0.2
Aug-04-2014	2	23.2	10,500	21	22.0	11.4	0.1
Aug-05-2014	1	25.7	10,500	NA	21.0	11.3	0.0
Aug-06-2014	1	27.9	10,500	NA	21.0	11.8	0.0
Aug-07-2014	1	28.8	10,600	NA	22.0	10.9	0.1
Aug-08-2014	2	27.0	10,900	NA	27.0	13.5	0.1
Aug-09-2014	1	27.2	10,900	NA	28.0	12.5	0.1
Aug-10-2014	1	23.8	10,900	NA	27.0	9.9	0.0
Aug-11-2014	0	27.3	10,900	27	26.0	9.1	0.0
Aug-12-2014	0	25.9	11,000	NA	27.0	8.3	0.0
Aug-13-2014	0	24.7	11,100	NA	26.0	5.8	0.0
Aug-14-2014	0	27.3	11,100	NA	28.0	7.1	0.0
Aug-15-2014	0	27.2	11,300	NA	27.0	11.8	0.0
Aug-16-2014	0	26.7	11,500	NA	27.0	9.4	0.0
Aug-17-2014	0	25.4	11,500	NA	28.0	8.6	0.0
Aug-18-2014	0	25.2	11,600	94	29.0	8.9	0.0
Aug-19-2014	0	24.3	11,800	NA	28.0	12.7	0.0
Aug-20-2014	0	24.7	11,900	NA	29.0	10.0	0.0
Aug-21-2014	0	24.9	12,000	NA	29.0	13.2	0.0
Aug-22-2014	0	26.0	12,000	NA	25.0	8.4	0.0
Aug-23-2014	0	24.3	12,000	NA	26.0	7.4	0.0
Aug-24-2014	0	24.6	12,000	NA	26.0	7.5	0.0
Aug-25-2014	0	23.1	12,100	29	25.0	8.7	0.0
Aug-26-2014	0	24.2	12,400	NA	25.0	8.0	0.0
Aug-27-2014	0	27.5	12,400	NA	25.0	9.3	0.0
Aug-28-2014	0	26.6	12,400	NA	26.0	9.9	0.0
Aug-29-2014	0	26.0	12,500	NA	27.0	9.8	0.0
Aug-30-2014	0	27.5	12,600	NA	26.0	11.2	0.0
Aug-31-2014	1	25.7	12,700	NA	26.0	11.9	0.1
Mean	6	28.1	9,710	28	19.1	10.9	0.0
						Total	
						(lbs)	1.3
Load							
Limitation for August 2014 (lbs)							75