

Continuous water monitoring at Station B (discharge from San Luis Drain), October 2014.

PARAMETER	Flow	Temperature	Specific Conductance	Total Suspended Solids	Boron	Selenium (total)	Selenium (total) Load
<b>DATA</b>							
<b>SOURCE</b>	<b>SLDMWA</b> ♦	<b>SLDMWA</b>	<b>SLDMWA</b>	<b>SLDMWA/USBR</b>	<b>USBR</b>	<b>USBR</b>	<b>Calculated</b>
<b>UNITS</b>	<b>cfs</b>	<b>°C</b>	<b>µS/cm</b>	<b>mg/L</b>	<b>mg/L</b>	<b>µg/L</b>	<b>lbs</b>
Oct-01-2014	0	22.1	15,400	NA	27.0	7.6	0.0
Oct-02-2014	0	21.9	15,100	NA	33.0	8.1	0.0
Oct-03-2014	0	23.3	15,100	NA	31.0	9.0	0.0
Oct-04-2014	0	23.6	15,000	NA	30.0	12.2	0.0
Oct-05-2014	0	24.0	15,000	NA	31.0	12.4	0.0
Oct-06-2014	0	24.4	14,900	NA	32.0	14.4	0.0
Oct-07-2014	0	23.8	15,100	NA	31.0	14.0	0.0
Oct-08-2014	0	23.4	15,000	NA	29.0	12.9	0.0
Oct-09-2014	0	22.9	15,000	NA	31.0	15.0	0.0
Oct-10-2014	0	20.9	15,000	NA	31.0	21.7	0.0
Oct-11-2014	0	21.8	15,100	NA	33.0	27.7	0.0
Oct-12-2014	0	22.0	15,200	NA	30.0	22.6	0.0
Oct-13-2014	0	22.1	15,400	99	32.0	15.4	0.0
Oct-14-2014	0	21.7	15,700	NA	31.0	9.9	0.0
Oct-15-2014	0	19.4	15,600	NA	32.0	11.0	0.0
Oct-16-2014	0	19.1	15,400	NA	32.0	10.9	0.0
Oct-17-2014	0	18.9	15,500	NA	32.0	10.0	0.0
Oct-18-2014	0	19.0	15,600	NA	36.0	11.0	0.0
Oct-19-2014	0	20.5	15,600	NA	34.0	13.0	0.0
Oct-20-2014	0	19.6	15,600	60	33.0	12.3	0.0
Oct-21-2014	1	15.9	15,600	NA	34.0	13.2	0.1
Oct-22-2014	1	16.9	15,600	NA	30.0	11.2	0.1
Oct-23-2014	2	18.6	15,600	NA	30.0	11.7	0.1
Oct-24-2014	2	19.2	15,800	NA	28.0	11.2	0.1
Oct-25-2014	2	17.7	15,700	NA	31.0	11.2	0.1
Oct-26-2014	2	15.4	15,500	NA	28.0	12.3	0.1
Oct-27-2014	2	14.7	15,400	98	26.0	12.7	0.1
Oct-28-2014	2	16.3	15,200	NA	28.0	13.8	0.1
Oct-29-2014	2	18.1	15,000	NA	26.0	14.6	0.2
Oct-30-2014	2	17.1	14,500	NA	27.0	13.0	0.2
Oct-31-2014	3	16.7	14,000	NA	25.0	12.1	0.2
<b>Mean</b>	<b>1</b>	<b>20.0</b>	<b>15,300</b>	<b>86</b>	<b>30.5</b>	<b>13.2</b>	<b>0.1</b>
						<b>Total (lbs)</b>	<b>1.7</b>
<b>Load</b>							
<b>Limitation for October 2014 (lbs)</b>							<b>55</b>