

Continuous water monitoring at Station B (discharge from San Luis Drain), November 2014.

PARAMETER	Flow	Temperature	Specific Conductance	Total Suspended Solids	Boron	Selenium (total)	Selenium (total) Load
DATA							
SOURCE	SLDMWA ♦	SLDMWA	SLDMWA	SLDMWA/USBR	USBR	USBR	Calculated
UNITS	cfs	°C	µS/cm	mg/L	mg/L	µg/L	lbs
Nov-01-2014	5	14.4	12,900	NA	24.0	11.6	0.3
Nov-02-2014	27	12.5	10,800	NA	18.0	9.1	1.3
Nov-03-2014	43	12.8	6,390	104	12.0	7.6	1.8
Nov-04-2014	30	13.5	5,990	NA	18.0	14.2	2.3
Nov-05-2014	22	14.8	7,320	NA	16.0	15.4	1.8
Nov-06-2014	17	15.9	6,870	NA	15.0	22.0	2.0
Nov-07-2014	15	16.6	6,980	NA	16.0	21.0	1.7
Nov-08-2014	13	16.8	7,530	NA	23.0	16.7	1.2
Nov-09-2014	7	16.9	9,350	NA	25.0	15.8	0.6
Nov-10-2014	6	16.6	10,400	67	26.0	15.6	0.5
Nov-11-2014	5	15.0	10,600	NA	27.0	15.9	0.4
Nov-12-2014	5	16.8	10,700	NA	26.0	15.6	0.4
Nov-13-2014	6	15.4	11,000	NA	28.0	15.3	0.5
Nov-14-2014	6	16.1	11,000	NA	27.0	15.1	0.5
Nov-15-2014	6	14.3	11,200	NA	30.0	14.5	0.4
Nov-16-2014	6	11.3	11,400	NA	26.0	13.6	0.4
Nov-17-2014	6	10.9	11,600	51	28.0	12.2	0.4
Nov-18-2014	6	9.7	11,700	NA	27.0	10.8	0.3
Nov-19-2014	6	13.4	11,800	NA	27.0	10.1	0.3
Nov-20-2014	6	12.3	11,600	NA	24.0	10.4	0.3
Nov-21-2014	6	12.8	11,400	NA	28.0	10.4	0.3
Nov-22-2014	5	11.9	11,200	NA	NA	9.7	0.3
Nov-23-2014	7	12.7	11,100	NA	NA	9.1	0.3
Nov-24-2014	7	9.7	11,200	NA	NA	8.6	0.3
Nov-25-2014	6	10.6	11,000	NA	NA	8.1	0.3
Nov-26-2014	6	11.2	10,700	NA	NA	6.6	0.2
Nov-27-2014	6	12.1	10,600	NA	NA	6.1	0.2
Nov-28-2014	6	10.4	10,500	NA	NA	5.9	0.2
Nov-29-2014	8	10.6	10,500	NA	NA	5.1	0.2
Nov-30-2014	9	10.5	10,700	NA	NA	4.1	0.2
Mean	10	13.3	10,200	74	23.4	11.9	0.7
						Total (lbs)	20
Load							
Limitation for November 2014 (lbs)							55