

Continuous water monitoring at Station B (discharge from San Luis Drain), December 2014.

PARAMETER	Flow	Temperature	Specific Conductance	Total Suspended Solids	Boron	Selenium (total)	Selenium (total) Load
DATA							
SOURCE	SLDMWA ♦	SLDMWA	SLDMWA	SLDMWA/USBR	USBR	USBR	Calculated
UNITS	cfs	°C	µS/cm	mg/L	mg/L	µg/L	lbs
Dec-01-2014	11	11.3	11,300	43	NA	3.9	0.2
Dec-02-2014	22	11.7	9,550	NA	11.0	5.9	0.7
Dec-03-2014	35	15.5	5,320	NA	12.0	7.3	1.4
Dec-04-2014	62	16.4	6,470	NA	15.0	12.0	4.0
Dec-05-2014	69	14.3	6,810	NA	15.0	15.8	5.9
Dec-06-2014	40	17.2	7,080	NA	16.0	26.8	5.8
Dec-07-2014	14	12.7	7,110	NA	17.0	22.0	1.7
Dec-08-2014	11	12.8	7,180	38	17.0	18.9	1.1
Dec-09-2014	9	12.1	7,230	NA	17.0	16.4	0.8
Dec-10-2014	7	11.9	7,250	NA	18.0	14.4	0.5
Dec-11-2014	9	14.1	7,280	NA	18.0	13.2	0.7
Dec-12-2014	42	12.2	6,980	NA	15.0	10.5	2.4
Dec-13-2014	88	10.9	6,410	NA	14.0	14.6	6.9
Dec-14-2014	101	11.6	5,440	NA	12.0	14.5	7.9
Dec-15-2014	101	9.4	4,450	78	9.8	20.4	11.1
Dec-16-2014	82	14.7	4,480	NA	12.0	21.2	9.4
Dec-17-2014	66	12.6	4,420	NA	14.0	24.1	8.5
Dec-18-2014	78	12.3	5,920	NA	13.0	26.6	11.2
Dec-19-2014	85	10.4	6,260	NA	13.0	20.4	9.4
Dec-20-2014	69	13.2	6,110	NA	14.0	24.1	9.0
Dec-21-2014	56	15.0	6,060	NA	13.0	25.2	7.6
Dec-22-2014	49	13.6	6,210	57	13.0	30.5	8.1
Dec-23-2014	46	13.3	6,460	NA	13.0	29.5	7.4
Dec-24-2014	45	10.4	6,500	NA	15.0	30.3	7.3
Dec-25-2014	46	10.8	6,550	NA	14.0	31.4	7.7
Dec-26-2014	52	7.3	6,640	NA	13.0	32.1	9.0
Dec-27-2014	44	6.3	6,630	NA	14.0	36.7	8.8
Dec-28-2014	38	8.2	6,820	NA	13.0	38.0	7.7
Dec-29-2014	24	7.3	6,820	27	14.0	38.8	5.1
Dec-30-2014	16	6.8	6,900	NA	14.0	38.4	3.3
Dec-31-2014	14	5.2	6,890	NA	14.0	37.3	2.8
Mean	46	11.7	6,630	49	14.1	22.6	5.6
						Total	
						(lbs)	173
Load							
Limitation for December 2014 (lbs)							152