

Continuous water monitoring at Station B (discharge from San Luis Drain), February 2015.

| PARAMETER | Flow | Temperature | Specific Conductance | Total Suspended Solids | Boron | Selenium (total) | Selenium (total) Load |
|--|-----------------|---------------|----------------------|------------------------|-------------|--------------------|-----------------------|
| DATA | | | | | | | |
| SOURCE | SLDMWA ↕ | SLDMWA | SLDMWA | SLDMWA/USBR | USBR | USBR | Calculated |
| UNITS | cfs | °C | µS/cm | mg/L | mg/L | µg/L | lbs |
| Feb-01-2015 | 7 | 10.8 | 8,683 | | 16.0 | 24.9 | 0.9 |
| Feb-02-2015 | 6 | 13.2 | 8,610 | 53 | 17.0 | 26.1 | 0.8 |
| Feb-03-2015 | 6 | 12.9 | 8,404 | | 17.0 | 26.2 | 0.8 |
| Feb-04-2015 | 6 | 12.5 | 8,351 | | 16.0 | 25.9 | 0.9 |
| Feb-05-2015 | 6 | 12.0 | 8,478 | | 16.0 | 23.8 | 0.8 |
| Feb-06-2015 | 18 | 16.3 | 7,647 | | 14.0 | 21.9 | 2.2 |
| Feb-07-2015 | 44 | 16.6 | 6,541 | | 13.0 | 14.5 | 3.4 |
| Feb-08-2015 | 45 | 16.4 | 6,114 | | 16.0 | 14.1 | 3.4 |
| Feb-09-2015 | 36 | 17.9 | 8,079 | | 16.0 | 20.9 | 4.1 |
| Feb-10-2015 | 24 | 13.1 | 7,294 | | 14.0 | 29.1 | 3.8 |
| Feb-11-2015 | 9 | 13.3 | 6,992 | | 14.0 | 29.2 | 1.4 |
| Feb-12-2015 | 6 | 15.4 | 7,144 | | 15.0 | 29.9 | 1.0 |
| Feb-13-2015 | 6 | 15.5 | 7,057 | | 15.0 | 29.1 | 0.9 |
| Feb-14-2015 | 6 | 16.0 | 7,051 | | 15.0 | 28.1 | 0.9 |
| Feb-15-2015 | 6 | 15.1 | 7,079 | | 14.0 | 28.0 | 0.8 |
| Feb-16-2015 | 6 | 15.1 | 7,084 | | 13.0 | 26.5 | 0.8 |
| Feb-17-2015 | 6 | 13.3 | 7,057 | 12 | 13.0 | 24.0 | 0.7 |
| Feb-18-2015 | 6 | 14.5 | 6,882 | | 12.0 | 22.1 | 0.7 |
| Feb-19-2015 | 6 | 12.0 | 6,685 | | 10.0 | 21.0 | 0.6 |
| Feb-20-2015 | 6 | 13.0 | 6,468 | | 10.0 | 19.1 | 0.6 |
| Feb-21-2015 | 6 | 12.3 | 6,283 | | 9.4 | 18.2 | 0.5 |
| Feb-22-2015 | 6 | 10.0 | 6,150 | | 9.6 | 17.3 | 0.5 |
| Feb-23-2015 | 6 | 9.7 | 6,062 | 16 | 9.8 | 16.3 | 0.5 |
| Feb-24-2015 | 12 | 11.0 | 6,058 | | 9.2 | 13.6 | 0.9 |
| Feb-25-2015 | 29 | 10.8 | 4,545 | | 6.5 | 5.8 | 0.9 |
| Feb-26-2015 | 25 | 12.7 | 4,025 | | 8.1 | 4.6 | 0.6 |
| Feb-27-2015 | 26 | 13.6 | 5,611 | | 16.0 | 10.4 | 1.5 |
| Feb-28-2015 | 31 | 11.4 | 7,154 | | 15.0 | 17.7 | 3.0 |
| . | . | . | . | . | . | . | . |
| . | . | . | . | . | . | . | . |
| . | . | . | . | . | . | . | . |
| Mean | 14 | 13.0 | 6,910 | 27 | 13.2 | 21.0 | 1.3 |
| | | | | | | Total (lbs) | 40 |
| Load Limitation for February 2015 (lbs) | | | | | | | 73 |