

Continuous water monitoring at Station B (discharge from San Luis Drain), June 2015.

PARAMETER	Flow	Temperature	Specific Conductance	Total Suspended Solids	Boron	Selenium (total)	Selenium (total) Load
DATA							
SOURCE	SLDMWA ↕	SLDMWA	SLDMWA	SLDMWA/USBR	USBR	USBR	Calculated
UNITS	cfs	°C	µS/cm	mg/L	mg/L	µg/L	lbs
Jun-01-2015	0	21.6	8,317	149	19.0	6.3	0.0
Jun-02-2015	0	22.6	8,629		20.0	6.4	0.0
Jun-03-2015	0	22.5	8,816		19.0	6.5	0.0
Jun-04-2015	0	21.8	8,776		20.0	6.1	0.0
Jun-05-2015	0	24.9	8,817		16.0	6.8	0.0
Jun-06-2015	0	26.2	8,794		16.0	7.1	0.0
Jun-07-2015	0	28.0	8,920		17.0	7.4	0.0
Jun-08-2015	0	31.6	9,172	156			0.0
Jun-09-2015	0	28.0	9,240				0.0
Jun-10-2015	0	25.4	9,309				0.0
Jun-11-2015	0	27.7	9,237				0.0
Jun-12-2015	0	30.6	9,392				0.0
Jun-13-2015	0	30.4	9,507				0.0
Jun-14-2015	0	26.4	9,503				0.0
Jun-15-2015	0	24.1	9,525	120			0.0
Jun-16-2015	0	24.7	9,638				0.0
Jun-17-2015	0	27.1	9,767				0.0
Jun-18-2015	0	27.2	9,809				0.0
Jun-19-2015	0	25.6	9,862				0.0
Jun-20-2015	0	27.6	9,933		19.0	8.0	0.0
Jun-21-2015	0	25.7	9,980		20.0	7.8	0.0
Jun-22-2015	0	24.5	10,067		20.0	7.5	0.0
Jun-23-2015	0	25.6	10,265		18.0	7.3	0.0
Jun-24-2015	0	27.1	10,398		19.0	7.5	0.0
Jun-25-2015	0	30.4	10,513				0.0
Jun-26-2015	0	31.3	10,672				0.0
Jun-27-2015	0	28.3	10,793				0.0
Jun-28-2015	0	28.7	10,992	38			0.0
Jun-29-2015	0	27.7	11,044				0.0
Jun-30-2015	0	31.4	11,139				0.0
Mean	0	26.8	9,690	116	18.6	7.0	0.0
						Total (lbs)	0
Load							
Limitation for June 2015 (lbs)							54