

Continuous water monitoring at Station B (discharge from San Luis Drain), August 2015.

PARAMETER	Flow	Temperature	Specific Conductance	Total Suspended Solids	Boron	Selenium (total)	Selenium (total) Load
<b>DATA</b>							
SOURCE	SLDMWA	SLDMWA	SLDMWA	SLDMWA/USBR	USBR	USBR	Calculated
UNITS	cfs	°C	µS/cm	mg/L	mg/L	µg/L	lbs
Aug-01-2015	0	27.7	16,116				0.0
Aug-02-2015	0	26.0	16,258				0.0
Aug-03-2015	0	25.0	16,456				0.0
Aug-04-2015	0	22.9	16,583				0.0
Aug-05-2015	0	23.8	16,770				0.0
Aug-06-2015	0	24.6	16,877				0.0
Aug-07-2015	0	26.9	17,063				0.0
Aug-08-2015	0	25.5	17,161				0.0
Aug-09-2015	0	26.0	17,399				0.0
Aug-10-2015	0	26.1	17,765				0.0
Aug-11-2015	0	25.4	17,861				0.0
Aug-12-2015	0	25.5	18,192				0.0
Aug-13-2015	0	25.7	18,506				0.0
Aug-14-2015	0	25.1	18,977				0.0
Aug-15-2015	0	26.4	19,403				0.0
Aug-16-2015	0	29.5	19,989				0.0
Aug-17-2015	0	30.2	20,799				0.0
Aug-18-2015	0	27.5	21,157				0.0
Aug-19-2015	0	25.4	21,053				0.0
Aug-20-2015	0	24.6	21,296				0.0
Aug-21-2015	0	24.4	21,650				0.0
Aug-22-2015	0	25.0	21,964				0.0
Aug-23-2015	0	25.1	22,117				0.0
Aug-24-2015	0	25.6	22,344				0.0
Aug-25-2015	0	27.2	22,578				0.0
Aug-26-2015	0	27.9	22,769				0.0
Aug-27-2015	0	28.9	23,132				0.0
Aug-28-2015	0	30.5	23,873				0.0
Aug-29-2015	0	26.8	21,757				0.0
Aug-30-2015	0	23.2	22,013				0.0
Aug-31-2015	0	24.5	25,309				0.0
<b>Mean</b>	0	26.1	19,800	NA	NA	NA	0.0
						<b>Total (lbs)</b>	0
<b>Load</b>							
<b>Limitation for August 2015 (lbs)</b>							59