

Continuous water monitoring at Station B (discharge from San Luis Drain), December 2015.

PARAMETER	Flow	Temperature	Specific Conductance	Total Suspended Solids	Boron	Selenium (total)	Selenium (total) Load
DATA							
SOURCE	SLDMWA ↕	SLDMWA	SLDMWA	SLDMWA/USBR	USBR	USBR	Calculated
UNITS	cfs	°C	µS/cm	mg/L	mg/L	µg/L	lbs
Dec-01-2015	12	7.2	7,287		12.0	16.4	1.0
Dec-02-2015	5	7.2	7,069		12.9	15.6	0.5
Dec-03-2015	5	8.8	7,144		12.8	15.4	0.4
Dec-04-2015	4	9.6	7,254		12.4	15.5	0.3
Dec-05-2015	4	7.4	7,250		13.0	15.1	0.3
Dec-06-2015	4	11.4	7,168		13.0	15.6	0.4
Dec-07-2015	4	11.7	7,106		12.9	16.6	0.4
Dec-08-2015	4	11.1	7,120		13.0	16.5	0.4
Dec-09-2015	5	13.6	7,067		10.8	16.8	0.4
Dec-10-2015	11	10.3	7,071		10.4	15.4	0.9
Dec-11-2015	30	13.2	6,327		9.5	10.9	1.7
Dec-12-2015	30	9.8	6,500		9.2	10.5	1.7
Dec-13-2015	19	8.3	4,202		6.5	7.3	0.8
Dec-14-2015	17	8.3	7,236	13	14.4	16.8	1.5
Dec-15-2015	26	4.6	9,108		14.8	20.5	2.8
Dec-16-2015	21	4.7	8,685		15.0	21.4	2.5
Dec-17-2015	25	5.8	8,589		15.5	17.5	2.3
Dec-18-2015	24	6.3	8,387		14.0	21.6	2.8
Dec-19-2015	26	9.2	7,756		14.1	24.0	3.3
Dec-20-2015	32	6.1	7,788		13.6	21.2	3.7
Dec-21-2015	22	9.7	7,680		13.9	19.1	2.3
Dec-22-2015	27	16.5	7,610		13.9	18.3	2.6
Dec-23-2015	22	9.5	7,706		13.9	19.0	2.3
Dec-24-2015	28	5.7	7,866		14.1	20.2	3.0
Dec-25-2015	26	6.4	7,949		13.7	21.1	2.9
Dec-26-2015	23	5.8	7,873		13.7	24.6	3.0
Dec-27-2015	22				13.2	22.9	2.7
Dec-28-2015	18		6,820		13.8	20.5	2.0
Dec-29-2015	17		6,822		13.8	18.6	1.7
Dec-30-2015	16		6,800		13.4	17.8	1.5
Dec-31-2015	14				12.6	17.1	1.3
Mean	17	8.7	7,350	13	12.9	17.7	1.7
						Total (lbs)	50
Load Limitation for December 2015 (lbs)							119