

Continuous water monitoring at Station B (discharge from San Luis Drain), February 2016.

PARAMETER	Flow	Temperature	Specific Conductance	Total Suspended Solids	Boron	Selenium (total)	Selenium (total) Load
<b>DATA</b>							
<b>SOURCE</b>	<b>SLDMWA</b> ♦	<b>SLDMWA</b>	<b>SLDMWA</b>	<b>SLDMWA/USBR</b>	<b>USBR</b>	<b>USBR</b>	<b>Calculated</b>
<b>UNITS</b>	<b>cfs</b>	<b>°C</b>	<b>µS/cm</b>	<b>mg/L</b>	<b>mg/L</b>	<b>µg/L</b>	<b>lbs</b>
Feb-01-2016	70	9.0	5,200	36	8.6	21.2	8.1
Feb-02-2016	76	6.8	5,880		8.8	21.3	8.7
Feb-03-2016	53	10.1	5,230		7.9	23.6	6.8
Feb-04-2016	49	8.1	5,090		8.4	30.7	8.1
Feb-05-2016	44	9.0	4,910		7.7	28.1	6.7
Feb-06-2016	35	10.5	4,810		7.3	29.0	5.4
Feb-07-2016	34	11.7	4,500		6.9	27.9	5.2
Feb-08-2016	30	12.4	4,710	17	7.4	29.1	4.7
Feb-09-2016	22	13.0	4,950		7.9	31.3	3.8
Feb-10-2016	23	13.6	5,670		9.5	35.7	4.4
Feb-11-2016	26	13.4	5,850		9.8	40.6	5.6
Feb-12-2016	25	14.0	5,970		10.1	41.5	5.7
Feb-13-2016	10	14.5	6,110		9.9	42.0	2.2
Feb-14-2016	7	14.2	6,090		11.5	43.0	1.7
Feb-15-2016	7	15.0	6,450		12.7	43.4	1.6
Feb-16-2016	7	14.9	7,210	19	13.0	42.6	1.5
Feb-17-2016	6	16.0	7,560		13.8	40.6	1.4
Feb-18-2016	5	11.6	7,620		13.7	38.1	1.0
Feb-19-2016	5	11.7	7,610		12.8	36.2	0.9
Feb-20-2016	4	11.6	7,550		12.0	34.1	0.8
Feb-21-2016	4	12.1	7,390		11.7	32.8	0.8
Feb-22-2016	5	12.0	7,100	25	11.4	31.7	0.9
Feb-23-2016	6	13.2	6,870		11.3	30.8	0.9
Feb-24-2016	6	13.9	6,740		11.0	30.1	0.9
Feb-25-2016	6	15.5	6,610		10.9	29.5	0.9
Feb-26-2016	6	15.0	6,560		10.8	28.9	0.9
Feb-27-2016	6	15.6	6,570		10.5	27.8	0.8
Feb-28-2016	6	14.0	6,550		10.2	26.8	0.8
Feb-29-2016	6	10.8	6,520	16	9.6	26.3	0.8
<b>Mean</b>	20	12.5	6,200	23	10.2	32.6	3.2
						<b>Total</b>	
						<b>(lbs)</b>	92
<b>Load</b>							
<b>Limitation for February 2016 (lbs)</b>							104