

Continuous water monitoring at Station B (discharge from San Luis Drain), April 2016.

PARAMETER	Flow	Temperature	Specific Conductance	Total Suspended Solids	Boron	Selenium (total)	Selenium (total) Load
<b>DATA</b>							
<b>SOURCE</b>	<b>SLDMWA</b> ◆	<b>SLDMWA</b>	<b>SLDMWA</b>	<b>SLDMWA/USBR</b>	<b>USBR</b>	<b>USBR</b>	<b>Calculated</b>
<b>UNITS</b>	<b>cfs</b>	<b>°C</b>	<b>µS/cm</b>	<b>mg/L</b>	<b>mg/L</b>	<b>µg/L</b>	<b>lbs</b>
Apr-01-2016	4	17.1	5,300		8.6	16.5	0.4
Apr-02-2016	4	19.0	5,310		8.4	15.8	0.4
Apr-03-2016	7	19.3	5,300		7.9	15.1	0.5
Apr-04-2016	9	17.7	5,080		7.3	14.2	0.7
Apr-05-2016	8	18.6	4,750		6.9	12.0	0.5
Apr-06-2016	10	20.9	4,510		6.7	10.2	0.6
Apr-07-2016	11	20.1	4,430		7.7	11.8	0.7
Apr-08-2016	11	19.3	5,080		7.4	9.6	0.5
Apr-09-2016	14	16.0	4,680		5.2	6.5	0.5
Apr-10-2016	52	15.8	5,270		12.3	13.9	3.9
Apr-11-2016	75	18.7	7,410	11	12.4	28.6	11.6
Apr-12-2016	28	17.9	7,120		12.0	25.9	3.9
Apr-13-2016	7	16.9	6,640		0.0	25.1	1.0
Apr-14-2016	5	15.5	6,260		0.0	25.0	0.7
Apr-15-2016	4	15.9	6,210		0.0	25.5	0.5
Apr-16-2016	5	18.3	6,240		0.0	25.0	0.6
Apr-17-2016	5	20.4	6,280		0.0	24.7	0.6
Apr-18-2016	5	23.2	6,270		0.0	24.5	0.6
Apr-19-2016	4	22.8	6,310		0.0	24.6	0.6
Apr-20-2016	3	21.4	6,300		10.6	22.8	0.4
Apr-21-2016	2	20.3	6,310		10.6	22.3	0.3
Apr-22-2016	3	16.2	6,280		10.7	21.8	0.3
Apr-23-2016	2	16.7	6,260		10.7	21.1	0.3
Apr-24-2016	3	16.5	6,250		10.6	21.1	0.3
Apr-25-2016	2	14.4	6,230	ND	10.6	21.2	0.2
Apr-26-2016	2	15.8	6,300		11.1	21.9	0.2
Apr-27-2016	2	14.6	6,300		0.0	0.0	0.0
Apr-28-2016	2	17.2	6,280		0.0	0.0	0.0
Apr-29-2016	2	18.1	6,280		0.0	0.0	0.0
Apr-30-2016	1	20.1	6,290		0.0	0.0	0.0
<b>Mean</b>	10	18.2	5,920	11	5.9	16.9	1.0
						<b>Total (lbs)</b>	31
<b>Load</b>							
<b>Limitation for April 2016 (lbs)</b>							108