

Continuous water monitoring at Station B (discharge from San Luis Drain), July 2016.

PARAMETER	Flow	Temperature	Specific Conductance	Total Suspended Solids	Boron	Selenium (total)	Selenium (total) Load
DATA							
SOURCE	SLDMWA ♦	SLDMWA	SLDMWA	SLDMWA/USBR	USBR	USBR	Calculated
UNITS	cfs	°C	µS/cm	mg/L	mg/L	µg/L	lbs
Jul-01-2016	0	29.7	8,390		15.6	8.8	0.0
Jul-02-2016	0	28.3	8,450		15.7	8.6	0.0
Jul-03-2016	0	27.0	8,440		16.2	9.1	0.0
Jul-04-2016	0	26.6	8,460		15.2	9.7	0.0
Jul-05-2016	0	25.1	8,720		16.5	9.0	0.0
Jul-06-2016	0	24.2	8,820		17.1	9.3	0.0
Jul-07-2016	0	24.6	8,840		16.4	8.1	0.0
Jul-08-2016	0	24.6	8,870		16.6	8.2	0.0
Jul-09-2016	0	24.8	8,920		17.0	8.3	0.0
Jul-10-2016	0	21.5	8,970		16.7	8.6	0.0
Jul-11-2016	0	24.3	9,040		17.1	9.0	0.0
Jul-12-2016	0	25.5	9,210		17.3	8.9	0.0
Jul-13-2016	0	26.6	9,280		17.6	9.0	0.0
Jul-14-2016	0	29.7	9,370		17.7	9.3	0.0
Jul-15-2016	0	28.3	9,380		17.9	9.0	0.0
Jul-16-2016	0	26.3	9,440		17.8	8.5	0.0
Jul-17-2016	0	26.1	9,560		18.0	8.2	0.0
Jul-18-2016	0	23.7	9,550		17.9	8.2	0.0
Jul-19-2016	0	23.9	9,580		18.1	8.6	0.0
Jul-20-2016	0	25.2	9,600			7.8	0.0
Jul-21-2016	0	24.8	9,670			8.3	0.0
Jul-22-2016	0	25.0	9,730			8.4	0.0
Jul-23-2016	0	27.0	9,830			8.7	0.0
Jul-24-2016	0	29.5	9,960			8.4	0.0
Jul-25-2016	0	28.2	10,100			8.5	0.0
Jul-26-2016	0	28.9	10,260			8.8	0.0
Jul-27-2016	0	31.0	10,300			9.0	0.0
Jul-28-2016	0	30.9	10,390			9.5	0.0
Jul-29-2016	0	31.1	10,460			10.2	0.0
Jul-30-2016	0	30.5	10,540			10.1	0.0
Jul-31-2016	0	27.2	10,540			9.5	0.0
Mean	0	26.8	9,440		17.0	8.8	0.0
						Total	
						(lbs)	0
Load							
Limitation for July 2016 (lbs)							75