Continuous water monitoring at Station B (discharge from San Luis Drain), September 2016.

PARAMETER	Flow	Temperature	Specific Conductance	Total Suspended Solids	Boron	Selenium (total)	Selenium (total) Load
DATA SOURCE	SLDMWA♦	SLDMWA	SLDMWA	SLDMWA/USBR	USBR	USBR	Calculated
UNITS	cfs	°C	µS/cm	mg/L	mg/L	µg/L	lbs
Sep-01-2016	0	23.1	13,800		28.4	12.9	0.0
Sep-02-2016	0	23.9	13,800		28.6	13.0	0.0
Sep-03-2016	0	21.5	13,900		28.5	13.0	0.0
Sep-04-2016	0	20.6	14,000		28.6	13.5	0.0
Sep-05-2016	0	21.5	14,000		29.4	13.9	0.0
Sep-06-2016	0	23.9	14,000		29.0	14.4	0.0
Sep-07-2016	0	24.7	14,600		33.0	14.1	0.0
Sep-08-2016	0	24.7	14,700		32.3	14.0	0.0
Sep-09-2016	0	24.1	14,700		32.8	14.1	0.0
Sep-10-2016	0	26.0	14,700		32.7	13.8	0.0
Sep-11-2016	0	25.2	14,800		33.2	14.4	0.0
Sep-12-2016	0	20.4	14,800		32.9	14.4	0.0
Sep-13-2016	0	17.2	14,900		32.4	15.0	0.0
Sep-14-2016	0	20.2	15,500		34.0	14.3	0.0
Sep-15-2016	0	21.9	15,600		34.3	14.4	0.0
Sep-16-2016	0	22.4	15,500		34.2	14.4	0.0
Sep-17-2016	0	25.0	15,600		34.2	14.1	0.0
Sep-18-2016	0	26.1	15,700		34.6	14.7	0.0
Sep-19-2016	0	27.5	15,100		33.0	16.3	0.0
Sep-20-2016	0	26.3	14,700		31.3	16.2	0.0
Sep-21-2016	0	23.0	12,200		25.8	13.2	0.0
Sep-22-2016	4	16.8	11,700		24.7	12.7	0.3
Sep-23-2016	5	19.0	11,000		22.8	14.1	0.4
Sep-24-2016	6	21.5	9,220		18.0	15.5	0.5
Sep-25-2016	6	24.1	8,420		16.1	14.1	0.4
Sep-26-2016	6	25.8	7,230		13.1	11.9	0.4
Sep-27-2016	6	26.0	8,270		16.2	12.1	0.4
Sep-28-2016	6	25.9	5,240		8.9	11.8	0.4
Sep-29-2016	6	23.5	5,020		8.3	9.8	0.3
Sep-30-2016	6	19.8	4,180		6.7	8.7	0.3
Mean	2	23.1	12,600		26.6	13.6	0.1
						Total (lbs)	3.2
Load Limitation for September 2016 (lbs)							132