

Continuous water monitoring at Station B (discharge from San Luis Drain), November 2016.

PARAMETER	Flow	Temperature	Specific Conductance	Total Suspended Solids	Boron	Selenium (total)	Selenium (total) Load
DATA							
SOURCE	SLDMWA ♦	SLDMWA	SLDMWA	SLDMWA/USBR	USBR	USBR	Calculated
UNITS	cfs	°C	µS/cm	mg/L	mg/L	µg/L	lbs
Nov-01-2016	8	16.5	2,230				0.0
Nov-02-2016	8	15.6	2,240				0.0
Nov-03-2016	8	16.3	2,250				0.0
Nov-04-2016	8	15.9	2,240				0.0
Nov-05-2016	7	15.9	2,250				0.0
Nov-06-2016	7	17.0	2,210				0.0
Nov-07-2016	7	18.6	3,610				0.0
Nov-08-2016	7	17.7	5,530				0.0
Nov-09-2016	7	18.3	6,450				0.0
Nov-10-2016	7	17.9	7,120				0.0
Nov-11-2016	7	17.6	6,180				0.0
Nov-12-2016	7	18.7	6,240				0.0
Nov-13-2016	7	17.2	4,410				0.0
Nov-14-2016	7	16.1	3,860				0.0
Nov-15-2016	7	16.5	4,280				0.0
Nov-16-2016	7	13.2	3,490				0.0
Nov-17-2016	7	9.9	2,690				0.0
Nov-18-2016	7	10.7	2,490				0.0
Nov-19-2016	7	14.9	2,390				0.0
Nov-20-2016	7	12.8	2,320				0.0
Nov-21-2016	8	13.3	2,280				0.0
Nov-22-2016	12	11.5	2,290				0.0
Nov-23-2016	19	12.9	2,300				0.0
Nov-24-2016	12	8.8	2,290				0.0
Nov-25-2016	8	8.7	2,290				0.0
Nov-26-2016	8	8.4	2,300				0.0
Nov-27-2016	9	11.5	2,280				0.0
Nov-28-2016	29	10.7	2,240				0.0
Nov-29-2016	24	10.2	6,670				0.0
Nov-30-2016	12	9.2	6,570				0.0
Mean	9	14.1	3,530				0.0
						Total (lbs)	0
Load							
Limitation for November 2016 (lbs)							131