

Continuous water monitoring at Station B (discharge from San Luis Drain), December 2016.

PARAMETER	Flow	Temperature	Specific Conductance	Total Suspended Solids	Boron	Selenium (total)	Selenium (total) Load
DATA							
SOURCE	SLDMWA♦	SLDMWA	SLDMWA	SLDMWA/USBR	USBR	USBR	Calculated
UNITS	cfs	°C	µS/cm	mg/L	mg/L	µg/L	lbs
Dec-01-2016	12	9.2	6,569				0.0
Dec-02-2016	8	10.6	3,230		2.9	3.5	0.1
Dec-03-2016	8	9.2	3,480		3.5	7.5	0.1
Dec-04-2016	8	7.0	5,760		6.9	9.5	0.3
Dec-05-2016	8	8.5	7,090		9.0	10.0	0.4
Dec-06-2016	8	6.6	6,960		10.0	10.1	0.4
Dec-07-2016	8	10.0	6,890		9.9		0.4
Dec-08-2016	8	6.4	6,930		9.4		0.4
Dec-09-2016	8	10.1	6,760		9.1		0.4
Dec-10-2016	8	13.7	5,880		7.6		0.3
Dec-11-2016	8	15.1	4,820		5.8		0.3
Dec-12-2016	8	11.7	4,160		4.7		0.2
Dec-13-2016	8	10.3	3,440		3.7		0.2
Dec-14-2016	7	12.0	4,040		4.7		0.2
Dec-15-2016	7	12.0	2,650		2.8		0.1
Dec-16-2016	8	12.7	2,400		2.6	2.4	0.1
Dec-17-2016	32	10.4	2,260		2.3	2.2	0.4
Dec-18-2016	67	5.4	3,590		3.0	1.5	1.1
Dec-19-2016	48	3.3	9,190		19.2	18.1	4.9
Dec-20-2016	32	4.6	8,820		21.1	20.7	3.6
Dec-21-2016	23	5.3	5,480		12.6	23.1	1.6
Dec-22-2016	11	6.8	8,290		27.1	26.0	1.6
Dec-23-2016	8	6.7	8,280		27.1	26.3	1.1
Dec-24-2016	9	6.6	8,060		27.1	26.9	1.3
Dec-25-2016	30	5.8	7,530		22.8	22.1	3.7
Dec-26-2016	35	3.7	6,810		18.0	17.7	3.4
Dec-27-2016	29	4.3	6,560		15.1	10.9	2.3
Dec-28-2016	23	5.5	8,600		21.0	22.7	2.6
Dec-29-2016	18	5.7			33.9	32.7	3.4
Dec-30-2016	10	5.8			31.6	30.9	1.8
Dec-31-2016	7	6.1			31.8	30.4	1.3
Mean	17	8.1	5,880		13.5	16.9	1.2
						Total (lbs)	38
Load							
Limitation for December 2016 (lbs)							179