Continuous water monitoring at Station B (discharge from San Luis Drain), January 2017.

PARAMETER	Flow	Temperature	Specific Conductance	Total Suspended Solids	Boron	Selenium (total)	Selenium (total) Load
DATA SOURCE	SLDMWA♦	SLDMWA	SLDMWA	SLDMWA/USBR	USBR	USBR	Calculated
UNITS	cfs	°C	µS/cm	mg/L	mg/L	µg/L	lbs
Jan-01-2017	7	4.8	8,070			31.5	1.2
Jan-02-2017	7	6.7	7,830			34.3	1.2
Jan-03-2017	7	8.6	8,000			34.3	1.3
Jan-04-2017	16	11.2	7,740		12.2	27.5	2.4
Jan-05-2017	37	8.2	6,410		9.9	16.8	3.4
Jan-06-2017	33	4.4	3,250		4.6	5.6	1.0
Jan-07-2017	28	10.0	7,980		17.6	18.9	2.8
Jan-08-2017	35	14.8	8,180		13.7	24.8	4.7
Jan-09-2017	55	13.2	7,380		12.4	26.2	7.8
Jan-10-2017	84	12.1	7,650		12.6	28.1	12.8
Jan-11-2017	67	12.6	6,690		11.7	22.9	8.2
Jan-12-2017	61	10.1	5,860		10.6	23.1	7.6
Jan-13-2017	59	7.4	6,360		11.4	22.5	7.1
Jan-14-2017	53	5.8	6,310		11.6	22.0	6.3
Jan-15-2017	31	4.9	6,470		11.6	20.6	3.4
Jan-16-2017	25	6.0	5,900		10.8	22.5	3.0
Jan-17-2017	24	4.3	6,040		11.4	22.8	3.0
Jan-18-2017	27	7.0	6,440		12.1	21.6	3.1
Jan-19-2017	30	9.8	6,750		12.2	24.1	3.8
Jan-20-2017	71	10.2	6,770		12.1	29.8	11.5
Jan-21-2017	75	9.7	6,350		11.3	31.4	12.8
Jan-22-2017	60	9.8	5,600		9.8	25.4	8.2
Jan-23-2017	44	8.4	4,620		8.5	23.9	5.6
Jan-24-2017	47	6.4	4,850		10.2	27.1	6.9
Jan-25-2017	51	7.5	5,820		9.9	26.0	7.1
Jan-26-2017	44	8.1	5,860		9.4	27.1	6.5
Jan-27-2017	49	7.8	5,550		9.5	30.5	8.1
Jan-28-2017	48	9.0	6,300		10.3	32.1	8.4
Jan-29-2017	48	9.2	6,080		9.9	35.5	9.1
Jan-30-2017	46	8.5	6,450		10.1	38.5	9.5
Jan-31-2017	43	8.4	6,710		10.2	39.8	9.3
Mean	42	8.5	6,460		11.0	26.4	6.0
						Total (lbs)	187
Load Limitation for January 2017 (lbs)							74