Continuous water monitoring at Station B (discharge from San Luis Drain), March 2017.

PARAMETER	Flow	Temperature	Specific Conductance	Total Suspended Solids	Boron	Selenium (total)	Selenium (total) Load
DATA SOURCE	SLDMWA♦	SLDMWA	SLDMWA	SLDMWA/USBR	USBR	USBR	Calculated
UNITS	cfs	°C	µS/cm	mg/L	mg/L	µg/L	lbs
Mar-01-2017	52	10.2	6,430		10.0	61.0	17.2
Mar-02-2017	52	12.2	6,440		10.1	62.8	17.8
Mar-03-2017	56	13.3	6,400		9.9	73.8	22.2
Mar-04-2017	57	13.6	6,020		9.3	64.2	19.6
Mar-05-2017	53	10.2	5,680		8.7	64.8	18.7
Mar-06-2017	53	9.6	5,500		8.6	51.3	14.8
Mar-07-2017	39	11.4	5,680		9.8	54.9	11.6
Mar-08-2017	24	13.5	5,550		8.9	53.6	6.8
Mar-09-2017	14	15.8	5,540		8.6	68.6	5.2
Mar-10-2017	13	16.3	5,500		8.5	68.0	4.9
Mar-11-2017	16	17.9	5,500		8.3	61.7	5.4
Mar-12-2017	18	17.1	5,280		7.8	57.9	5.6
Mar-13-2017	16	17.9	4,960		7.2	52.4	4.5
Mar-14-2017	12	20.4	4,740		7.5	51.6	3.4
Mar-15-2017	13	20.2	4,120		4.4	14.6	1.0
Mar-16-2017	16	17.6	3,180		5.0	20.6	1.8
Mar-17-2017	14	19.8	3,920		7.2	25.9	2.0
Mar-18-2017	14	17.0	4,920		9.0	21.8	1.6
Mar-19-2017	12	17.3	5,680		8.4	17.3	1.1
Mar-20-2017	10	16.9	5,340		6.1	11.4	0.6
Mar-21-2017	11	16.4	4,080		4.8	14.3	0.9
Mar-22-2017	22	12.0	3,870		7.6	14.3	1.7
Mar-23-2017	52	13.6	4,670		6.1	18.4	5.2
Mar-24-2017	50	12.3	5,950		10.0	18.6	5.0
Mar-25-2017	40	15.4	7,070		10.3	34.5	7.5
Mar-26-2017	42	14.8	6,730		10.1	37.0	8.4
Mar-27-2017	42	14.3	6,550		9.5	31.0	7.0
Mar-28-2017	39	16.4	6,550		8.5	25.1	5.3
Mar-29-2017	31	18.0	6,520		11.1	35.0	5.9
Mar-30-2017	14	16.2	6,300		10.8	33.7	2.6
Mar-31-2017	11	15.6	6,350		11.2	32.6	2.0
Mean	29	15.3	5,120		8.5	40.4	7.0
						Total (lbs)	217
Load Limitation for March 2017 (lbs)							171