Continuous water monitoring at Station B (discharge from San Luis Drain), May 2017.

PARAMETER	Flow	Temperature	Specific Conductance	Total Suspended Solids	Boron	Selenium (total)	Selenium (total) Load
DATA SOURCE	SLDMWA♦	SLDMWA	SLDMWA	SLDMWA/USBR	USBR	USBR	Calculated
UNITS	cfs	°C	µS/cm	mg/L	mg/L	µg/L	lbs
May-01-2017	3	22.6	6,360		15.4	10.2	0.2
May-02-2017	3	25.1	6,650		14.7	10.8	0.2
May-03-2017	4	26.2	7,060		16.5	10.6	0.2
May-04-2017	4	27.5	7,390		16.1	11.1	0.2
May-05-2017	3	21.1	8,170		16.0	10.9	0.2
May-06-2017	4	16.4	8,160		16.6	10.9	0.2
May-07-2017	4	18.0	8,130		17.2	11.0	0.2
May-08-2017	5	21.0	8,170		17.6	11.1	0.3
May-09-2017	5	22.6	8,510		17.2	11.3	0.3
May-10-2017	5	20.4	8,890		18.5	11.4	0.3
May-11-2017	7	19.6	9,280		17.6	11.3	0.4
May-12-2017	8	17.5	9,480		14.8	11.0	0.5
May-13-2017	6	15.3	8,640		13.6	10.7	0.4
May-14-2017	6	16.0	7,950		12.9	10.4	0.3
May-15-2017	5	16.7	7,510		13.1	10.8	0.3
May-16-2017	5	17.4	7,470		15.9	11.3	0.3
May-17-2017	5	18.6	7,260		13.6	11.5	0.3
May-18-2017	5	19.7	7,170		13.8	11.6	0.3
May-19-2017	5	23.1	7,110		13.8	11.4	0.3
May-20-2017	5	25.8	7,200		13.1	10.8	0.3
May-21-2017	5	27.0	7,290		11.6	9.5	0.3
May-22-2017	5	28.0	7,180		9.9	8.2	0.2
May-23-2017	5	28.0	6,960		9.9	8.3	0.2
May-24-2017	5	24.6	6,610		8.3	8.1	0.2
May-25-2017	5	19.5	6,160		7.4	7.3	0.2
May-26-2017	5	19.3	5,760		6.5	7.3	0.2
May-27-2017	5	21.4	5,200		5.8	6.8	0.2
May-28-2017	5	23.0	4,750		5.5	6.6	0.2
May-29-2017	5	22.9	4,360		5.1	6.0	0.2
May-30-2017	5	22.7	3,930		6.3	6.9	0.2
May-31-2017	5	21.8	3,560		4.8	5.8	0.2
Mean	10	16.5	5,460		10.5	18.8	0.3
						Total (lbs)	8.1
Load Limitation for May 2017 (lbs)							179