Continuous water monitoring at Station B (discharge from San Luis Drain), June 2017.

PARAMETER	Flow	Temperature	Specific Conductance	Total Suspended Solids	Boron	Selenium (total)	Selenium (total) Load
DATA SOURCE	SLDMWA♦	SLDMWA	SLDMWA	SLDMWA/USBR	USBR	USBR	Calculated
UNITS	cfs	°C	µS/cm	mg/L	mg/L	µg/L	lbs
Jun-01-2017	5	23.2	3,350		5.0	6.4	0.2
Jun-02-2017	5	25.1	3,310		5.1	5.5	0.2
Jun-03-2017	5	26.0	3,330		5.3	5.7	0.2
Jun-04-2017	5	24.5	3,410		5.3	5.5	0.2
Jun-05-2017	5	23.1	3,470		5.1	5.4	0.2
Jun-06-2017	5	25.5	3,520		5.0	5.6	0.2
Jun-07-2017	5	23.5	3,530		4.7	5.6	0.2
Jun-08-2017	5	19.8	3,510		4.2	5.2	0.1
Jun-09-2017	5	22.4	3,450		4.1	5.0	0.1
Jun-10-2017	5	19.1	3,340		3.9	4.7	0.1
Jun-11-2017	5	17.8	3,210		3.8	4.5	0.1
Jun-12-2017	5	18.6	3,020		3.6	4.8	0.1
Jun-13-2017	5	21.2	2,910		3.5	4.9	0.1
Jun-14-2017	5	24.6	2,810		3.9	4.5	0.1
Jun-15-2017	16	24.8	2,690		3.6	4.6	0.4
Jun-16-2017	12	28.4	2,360		2.8	4.1	0.3
Jun-17-2017	5	30.0	2,310		2.7	4.0	0.1
Jun-18-2017	5	32.4	2,310		2.5	4.0	0.1
Jun-19-2017	5	34.2	2,330		2.5	3.9	0.1
Jun-20-2017	5	32.8	2,300		2.4	3.9	0.1
Jun-21-2017	2	31.1	2,240		2.6	4.5	0.1
Jun-22-2017	2	33.1	2,230		2.5	4.1	0.0
Jun-23-2017	1	31.1	2,230		2.5	4.0	0.0
Jun-24-2017	1	28.9	2,220		2.5	4.0	0.0
Jun-25-2017	1	28.3	2,220		2.5	4.1	0.0
Jun-26-2017	1	25.7	2,230		2.5	4.2	0.0
Jun-27-2017	0	24.9	2,240		2.5	4.7	0.0
Jun-28-2017	0	24.7	2,250		2.8	5.4	0.0
Jun-29-2017	0	25.3	2,270		2.8	5.4	0.0
Jun-30-2017	0	20.1	2,280		2.9	5.3	0.0
Mean	4	25.7	2,760		3.5	4.8	0.1
						Total (lbs)	3.4
Load Limitation for June 2017 (lbs)							124