

Continuous water monitoring at Station B (discharge from San Luis Drain), July 2017.

PARAMETER	Flow	Temperature	Specific Conductance	Total Suspended Solids	Boron	Selenium (total)	Selenium (total) Load
DATA							
SOURCE	SLDMWA ♦	SLDMWA	SLDMWA	SLDMWA/USBR	USBR	USBR	Calculated
UNITS	cfs	°C	µS/cm	mg/L	mg/L	µg/L	lbs
Jul-01-2017	0	24.4	2,280		2.9	5.3	0.0
Jul-02-2017	0	26.8	2,280		2.8	5.4	0.0
Jul-03-2017	0	27.3	2,280		2.9	5.4	0.0
Jul-04-2017	0	28.2	2,290		3.0	5.3	0.0
Jul-05-2017	0	27.5	2,300		3.6	6.2	0.0
Jul-06-2017	2	29.1	2,330		3.7	6.0	0.1
Jul-07-2017	3	30.0	2,360		4.1	6.0	0.1
Jul-08-2017	3	31.0	2,390		4.4	5.5	0.1
Jul-09-2017	3	30.2	2,480		4.9	5.7	0.1
Jul-10-2017	3	30.1	2,650		5.0	5.5	0.1
Jul-11-2017	3	29.2	2,810		5.1	5.7	0.1
Jul-12-2017	3	27.6	2,860			5.9	0.1
Jul-13-2017	3	28.1	2,940			5.6	0.1
Jul-14-2017	3	28.2	3,030			5.1	0.1
Jul-15-2017	3	27.3	3,060			5.5	0.1
Jul-16-2017	5	30.2	3,110			5.2	0.1
Jul-17-2017	5	30.2	3,210			5.3	0.1
Jul-18-2017	2	27.8	3,260			5.7	0.0
Jul-19-2017	0	25.2	3,280			6.4	0.0
Jul-20-2017	0	25.4	3,330			6.1	0.0
Jul-21-2017	1	26.1	3,370			5.6	0.0
Jul-22-2017	1	27.6	3,400			5.6	0.2
Jul-23-2017	1	30.1	3,440			5.7	0.0
Jul-24-2017	2	28.3	3,470			5.9	0.1
Jul-25-2017	4	26.1	3,490			6.1	0.1
Jul-26-2017	4	26.6	3,510			6.7	0.1
Jul-27-2017	3	28.4	3,530			6.4	0.1
Jul-28-2017	2	29.7	3,590			5.8	0.1
Jul-29-2017	2	27.5	3,620			5.9	0.1
Jul-30-2017	2	27.4	3,670			6.2	0.1
Jul-31-2017	2	27.9	3,730			6.3	0.1
Mean	2	28.0	3,010		3.8	7.4	0.1
						Total	
						(lbs)	2.2
Load							
Limitation for July 2017 (lbs)							125