

Continuous water monitoring at Station B (discharge from San Luis Drain), August 2017.

PARAMETER	Flow	Temperature	Specific Conductance	Total Suspended Solids	Boron	Selenium (total)	Selenium (total) Load
DATA							
SOURCE	SLDMWA ♦	SLDMWA	SLDMWA	SLDMWA/USBR	USBR	USBR	Calculated
UNITS	cfs	°C	µS/cm	mg/L	mg/L	µg/L	lbs
Aug-01-2017	2	30.0	3,710			7.0	0.1
Aug-02-2017	2	32.7	3,680				0.0
Aug-03-2017	2	31.8	3,670				0.0
Aug-04-2017	2	27.9	3,660				0.0
Aug-05-2017	2	28.4	3,640				0.0
Aug-06-2017	2	27.3	3,580				0.0
Aug-07-2017	2	25.7	3,510				0.0
Aug-08-2017	4	25.9	3,510				0.0
Aug-09-2017	4	26.2	3,400				0.0
Aug-10-2017	3	25.9	3,390				0.0
Aug-11-2017	3	26.3	3,380				0.0
Aug-12-2017	2	27.0	3,320				0.0
Aug-13-2017	2	26.1	3,270				0.0
Aug-14-2017	3	24.3	3,220				0.0
Aug-15-2017	2	22.8	3,200				0.0
Aug-16-2017	2	24.1	3,140				0.0
Aug-17-2017	1	26.5	3,110				0.0
Aug-18-2017	1	27.2	3,090				0.0
Aug-19-2017	0	26.8	3,100				0.0
Aug-20-2017	0	25.1	3,090				0.0
Aug-21-2017	0	24.0	3,100				0.0
Aug-22-2017	0	25.8	3,100				0.0
Aug-23-2017	0	26.2	3,100				0.0
Aug-24-2017	0	25.9	3,080				0.0
Aug-25-2017	0	25.7	3,090				0.0
Aug-26-2017	0	27.7	3,100				0.0
Aug-27-2017	0	29.4	3,110				0.0
Aug-28-2017	35	30.4	3,110				0.0
Aug-29-2017	22	28.7	3,140				0.0
Aug-30-2017	0	27.2	3,170				0.0
Aug-31-2017	0	25.7	3,170				0.0
Mean	3	26.9	3,290		3.8	7.4	0.0
						Total (lbs)	0.1
Load							
Limitation for August 2017 (lbs)							128