

Continuous water monitoring at Station B (discharge from San Luis Drain), September 2017.

PARAMETER	Flow	Temperature	Specific Conductance	Total Suspended Solids	Boron	Selenium (total)	Selenium (total) Load
DATA							
SOURCE	SLDMWA ♦	SLDMWA	SLDMWA	SLDMWA/USBR	USBR	USBR	Calculated
UNITS	cfs	°C	µS/cm	mg/L	mg/L	µg/L	lbs
Sep-01-2017	0	28.6	3,180		4.2	7.8	0.0
Sep-02-2017	1	31.1	3,190		4.1	8.6	0.0
Sep-03-2017	5	32.2	3,170		3.9	8.8	0.2
Sep-04-2017	5	29.3	3,090		3.6	7.9	0.2
Sep-05-2017	5	28.7	2,940		3.4	5.8	0.2
Sep-06-2017	5	28.3	2,760		3.4	4.3	0.1
Sep-07-2017	5	24.0	2,630		3.4	3.7	0.1
Sep-08-2017	5	24.4	2,610		3.0	3.5	0.1
Sep-09-2017	5	25.2	2,600		3.2	3.3	0.1
Sep-10-2017	5	27.1	2,540		3.7	3.4	0.1
Sep-11-2017	5	28.5	2,760		4.2	3.3	0.1
Sep-12-2017	5	27.8	3,170		4.4	3.3	0.1
Sep-13-2017	5	24.2	3,460		4.1	3.6	0.1
Sep-14-2017	5	22.2	3,490		3.7	3.8	0.1
Sep-15-2017	5	20.9	3,220		3.5	4.0	0.1
Sep-16-2017	6	22.9	3,030		3.3	3.7	0.1
Sep-17-2017	5	22.6	2,940		3.2	3.7	0.1
Sep-18-2017	5	21.4	2,870		3.1	3.7	0.1
Sep-19-2017	5	18.6	2,860		3.0	3.7	0.1
Sep-20-2017	6	21.0	2,840		3.1	3.7	0.1
Sep-21-2017	6	19.2	2,810		3.1	3.7	0.1
Sep-22-2017	6	17.2	2,770		3.0	3.4	0.1
Sep-23-2017	6	17.9	2,790		3.0	3.3	0.1
Sep-24-2017	6	17.7	2,800		3.1	3.1	0.1
Sep-25-2017	6	19.5	2,810		3.1	3.0	0.1
Sep-26-2017	6	21.4	2,840		3.0	2.9	0.1
Sep-27-2017	7	23.3	2,770		3.0	2.8	0.1
Sep-28-2017	7	24.2	2,720		3.0	2.8	0.1
Sep-29-2017	7	23.0	2,660		3.0	2.7	0.1
Sep-30-2017	7	21.1	2,650		2.9	2.6	0.1
Mean	5	23.8	2,900		3.4	4.1	0.1
						Total (lbs)	3.2
Load							
Limitation for September 2017 (lbs)							116