Continuous water monitoring at Station B (discharge from San Luis Drain), January 2018.

PARAMETER	Flow	Temperature	Specific Conductance	Total Suspended Solids	Boron	Selenium (B3) (total)	Selenium (B2) (total)	Selenium (total) Load
DATA SOURCE	SLDMWA♦	SLDMWA	SLDMWA	SLDMWA/USBR	USBR	SLDMWA	USBR	Calculated
UNITS	cfs	°C	µS/cm	mg/L	mg/L	µg/L	µg/L	lbs
Jan-01-2018	10	10.7	2,510		2.8	1.4	1.2	0.1
Jan-02-2018	10	9.4	2,500		3.4	1.2	1.2	0.1
Jan-03-2018	10	8.6	2,500		3.4	1.2	1.2	0.1
Jan-04-2018	12	13.6	2,470		3.4	1.2	0.8	0.1
Jan-05-2018	16	14.9	2,490		3.4	1.2	1.2	0.1
Jan-06-2018	13	13.6	2,520		3.4	1.3	1.2	0.1
Jan-07-2018	13	12.7	2,530		3.4	1.3	1.2	0.1
Jan-08-2018	15	12.3	2,490		3.3	1.3	1.3	0.1
Jan-09-2018	30	13.3	2,390		3.0	1.3	1.2	0.2
Jan-10-2018	86	12.5	2,410		7.3	4.7	1.2	0.5
Jan-11-2018	102	13.0	7,790		16.2	15.5	12.3	6.8
Jan-12-2018	80	8.8	7,640		13.5	15.6	14.2	6.1
Jan-13-2018	72	10.6	6,920		12.6	20.3	18.9	7.4
Jan-14-2018	72	9.9	6,860		12.5	22.0	21.1	8.3
Jan-15-2018	68	10.7	7,000		12.5	22.2	22.9	8.4
Jan-16-2018	65	12.5	6,610		11.3	21.6	21.7	7.6
Jan-17-2018	50	13.1	6,460		11.5	24.3	24.4	6.5
Jan-18-2018	22	12.9	6,340		11.5	24.1	25.0	2.9
Jan-19-2018	15	11.5	6,540		11.5	25.3		1.0
Jan-20-2018	14	8.7	6,630		11.6	26.0		1.0
Jan-21-2018	14	7.3	6,630		11.4	22.8		0.8
Jan-22-2018	13	9.8	6,450		10.8	20.5		0.7
Jan-23-2018	13	9.9	6,300		10.8	21.8		0.8
Jan-24-2018	13	9.3	6,200		10.7	20.8		0.8
Jan-25-2018	13	11.0	6,160		9.4	17.5		0.6
Jan-26-2018	13	9.7	5,600		8.2	13.9		0.5
Jan-27-2018	12	10.3	4,980		7.0	10.3		0.3
Jan-28-2018	12	10.2	4,480		7.3	7.1		0.2
Jan-29-2018	12	9.2	3,920		5.0	5.5		0.2
Jan-30-2018	12	10.1	3,540		4.4	4.3	4.0	0.3
Jan-31-2018	12	11.5	3,080		4.3	3.8		0.1
Mean	29	11.0	4,870		8.1	12.3	9.3	2.0
							Total (lbs)	62.7
Load Limitation for January 2018 (lbs)								300