Continuous water monitoring at Station B (discharge from San Luis Drain), March 2018.

PARAMETER	Flow	Temperature	Specific Conductance	Total Suspended Solids	Boron	Selenium (B3) (total)	Selenium (B2) (total)	Selenium (total) Load
DATA SOURCE	SLDMWA♦	SLDMWA	SLDMWA	SLDMWA/USBR	USBR	SLDMWA	USBR	Calculated
UNITS	cfs	°C	µS/cm	mg/L	mg/L	µg/L	µg/L	lbs
Mar-01-2018	61	9.8	2,820		3.7	1.7	1.7	0.5
Mar-02-2018	58	11.0	3,000		10.3	9.3	2.0	0.6
Mar-03-2018	98	9.2	7,710		12.9	26.8	22.3	11.8
Mar-04-2018	124	8.4	7,110		14.2	20.2	26.1 U	17.5
Mar-05-2018	108	9.1	6,570		11.3	17.9	18.1	10.5
Mar-06-2018	76	12.2	5,730		10.6	17.9	19.0	7.8
Mar-07-2018	70	14.2	5,890		10.8	23.4		4.4
Mar-08-2018	64	18.0	5,640		9.7	23.4		4.1
Mar-09-2018	58	16.0	5,630		9.8	21.8		3.5
Mar-10-2018	50	13.2	5,640		9.6	24.7		3.4
Mar-11-2018	39	15.5	5,630		9.8	24.4		2.6
Mar-12-2018	39	17.1	5,690		9.7	25.9		2.7
Mar-13-2018	40	15.3	5,670		9.7	32.6		3.5
Mar-14-2018	37	12.3	5,570		8.7	32.6		3.3
Mar-15-2018	37	11.6	5,350		8.4	33.1	32.5	6.4
Mar-16-2018	34	11.1	5,310		8.5	34.6		3.2
Mar-17-2018	26	9.2	5,150		8.1	34.0		2.4
Mar-18-2018	17	10.0	5,100		8.5	32.2		1.5
Mar-19-2018	14	12.6	5,100		8.7	32.3		1.2
Mar-20-2018	12	11.7	5,220		9.4	29.7		1.0
Mar-21-2018	12	15.4	5,260		9.8	26.7		0.9
Mar-22-2018	41	16.0	3,500		9.6	23.6		2.7
Mar-23-2018	94	11.7	1,630		13.1	17.1	14.3	7.2
Mar-24-2018	72	11.4	1,950		22.7	24.8	22.6	8.7
Mar-25-2018	43	10.3	3,090		21.8	21.6	21.9	5.1
Mar-26-2018	28	12.0	3,080		20.8	23.9	21.8	3.3
Mar-27-2018	14	14.5	3,360		19.3	23.7	24.1	1.9
Mar-28-2018	9	14.0	2,040		18.6	23.4	24.1	1.2
Mar-29-2018	8	19.0	1,340		18.3	23.0	23.4	1.0
Mar-30-2018	8	20.0	1,100		18.1	23.0	23.4	1.0
Mar-31-2018	7	20.6	1,230		17.4	22.1	22.9	0.9
Mean	45	13.3	4,420		12.3	24.2	19.6	4.1
							Total (lbs)	126
Load Limitation for March 2018 (lbs)								184