

Continuous water monitoring at Station B (discharge from San Luis Drain), July 2018.

PARAMETER	Flow	Temperature	Specific Conductance	Total Suspended Solids	Boron	Selenium (B3) (total)	Selenium (B2) (total)	Selenium (total) Load
DATA SOURCE UNITS	SLDMWA [♦] cfs	SLDMWA °C	SLDMWA µS/cm	SLDMWA/USBR mg/L	USBR mg/L	SLDMWA µg/L	USBR µg/L	Calculated lbs
Jul-01-2018	2		2,400		3.0	2.3	2.3	0.0
Jul-02-2018	2		2,400		3.0	2.3	2.3	0.0
Jul-03-2018	2					2.6	2.6	0.0
Jul-04-2018	2					2.5	2.5	0.0
Jul-05-2018	2					2.2	2.2	0.0
Jul-06-2018	2					2.3	2.3	0.0
Jul-07-2018	2					2.3	2.3	0.0
Jul-08-2018	2					2.5	2.5	0.0
Jul-09-2018	2					2.8	2.8	0.0
Jul-10-2018	2		2,560		3.2	2.7	2.7	0.0
Jul-11-2018	2		2,560		3.2	2.5	2.5	0.0
Jul-12-2018	1		2,520		3.1	2.7	2.7	0.0
Jul-13-2018	1		2,540		3.2	2.7	2.7	0.0
Jul-14-2018	1		2,520		3.2	2.7	2.7	0.0
Jul-15-2018	1		2,520		3.4	2.6	2.6	0.0
Jul-16-2018	1		2,520		3.3	2.9	2.9	0.0
Jul-17-2018	1		2,620		3.4	2.8	2.8	0.0
Jul-18-2018	1		2,560		3.2	2.8	2.8	0.0
Jul-19-2018	1		2,450		3.1	2.5	2.5	0.0
Jul-20-2018	1		2,400		3.0	2.4	2.4	0.0
Jul-21-2018	1		2,420		3.0	2.6	2.6	0.0
Jul-22-2018	1		2,490		3.1	2.3	2.3	0.0
Jul-23-2018	1		2,540		3.2	2.1	2.1	0.0
Jul-24-2018	1		2,610		3.2	2.2	2.2	0.0
Jul-25-2018	1		2,580		3.3	2.1	2.1	0.0
Jul-26-2018	1		2,510		3.1	2.3	2.3	0.0
Jul-27-2018	1		2,440		2.9	2.5	2.5	0.0
Jul-28-2018	1		2,430		2.9	2.6	2.6	0.0
Jul-29-2018	2		2,450		3.0	2.5	2.5	0.0
Jul-30-2018	2		2,460		3.0	2.6	2.6	0.0
Jul-31-2018	1		2,510		3.1	2.8	2.8	0.0
Mean	2	NA	2,500		3.1	2.5	2.5	0.0
							Total (lbs)	0.6
Load Limitation for July 2018 (lbs)								131