

Continuous water monitoring at Station B (discharge from San Luis Drain), August 2018.

PARAMETER	Flow	Temperature	Specific Conductance	Total Suspended Solids	Boron	Selenium (B3) (total)	Selenium (B2) (total)	Selenium (total) Load
DATA SOURCE UNITS	SLDMWA [♦] cfs	SLDMWA °C	SLDMWA µS/cm	SLDMWA/USBR mg/L	USBR mg/L	SLDMWA µg/L	USBR µg/L	Calculated lbs
Aug-01-2018	1		2,490		3.0	2.5	2.5	0.0
Aug-02-2018	1		2,510		3.0	2.9	2.9	0.0
Aug-03-2018	1		2,540		3.1	2.7	2.7	0.0
Aug-04-2018	1		2,610		3.2	2.7	2.7	0.0
Aug-05-2018	1		2,720		3.4	2.8	2.8	0.0
Aug-06-2018	1		2,810		3.6	3.0	3.0	0.0
Aug-07-2018	1		2,990		3.3	2.4	2.4	0.0
Aug-08-2018	1		3,110		3.4	2.6	2.6	0.0
Aug-09-2018	1		3,160		3.5	2.5	2.5	0.0
Aug-10-2018	1		3,150		3.5	2.2	2.2	0.0
Aug-11-2018	1		3,150		3.5	2.5	2.5	0.0
Aug-12-2018	1		3,070		3.5	2.6	2.6	0.0
Aug-13-2018	1		2,970		3.4	2.6	2.6	0.0
Aug-14-2018	1		2,990		3.5	2.6	2.6	0.0
Aug-15-2018	1		2,920		3.5	2.8	2.8	0.0
Aug-16-2018	1		2,900		3.5	3.0	3.0	0.0
Aug-17-2018	1		2,890		3.5	2.7	2.7	0.0
Aug-18-2018	1		2,850		3.5	2.7	2.7	0.0
Aug-19-2018	1		2,790		3.5	2.9	2.9	0.0
Aug-20-2018	1		2,740		3.5	2.9	2.9	0.0
Aug-21-2018	1		2,720		3.1	2.8	2.8	0.0
Aug-22-2018	1		2,670		3.0	2.8	2.8	0.0
Aug-23-2018	1		2,630		3.0	2.9	2.9	0.0
Aug-24-2018	1		2,620		3.0	2.5	2.5	0.0
Aug-25-2018	1		2,660		3.1	2.8	2.8	0.0
Aug-26-2018	1		2,710		3.1	2.8	2.8	0.0
Aug-27-2018	1		2,780		3.1	3.0	3.0	0.0
Aug-28-2018	1		2,880		3.2	3.1	3.1	0.0
Aug-29-2018	1		2,900		3.2	3.2	3.2	0.0
Aug-30-2018	1		2,900		2.9	3.5	3.5	0.0
Aug-31-2018	1		2,860		2.9	2.8	2.8	0.0
Mean	1	NA	2,830		3.3	2.8	2.8	0.0
							Total (lbs)	0.5
Load								
Limitation for August 2018 (lbs)								137